


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County		Fraction		Section number		Township number		Range number	
1. Location of well: Ness		1/4 NW 1/4 SE 1/4		15		T 16 S		R 24 E/W	
2. Distance and direction from nearest town or city: 1 mi. West, 1N, 1/4W, 1/4N, 100 ft. East Street address of well location if in city:				3. Owner of well: City of Ransom R.R. or street: City, state, zip code: Ransom, KS 67572					
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W 1 Mile E S 1 Mile</div> 				Sketch map:		6. Bore hole dia. 26 in. Completion date 6-15-78 Well depth 52 ft.			
5. Type and color of material				From		To		7. Cable tool Rotary Driven Dug Hollow rod Jetted Bored X Reverse rotary	
Top soil				0		4		8. Use: Domestic X Public supply Industry Irrigation Air conditioning Stock Lawn Oil field water Other	
Brown clay				4		10		9. Casing: Material Steel Height: Above or below Threaded Welded X Surface 24 in. RMP PVC Weight 43.77 lbs./ft. Dia. 12-3/4 in. to 52 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 330	
Fine to med. sand and gravel, loose				10		48		10. Screen: Manufacturer's name Johnson Type Irrigator Dia. 12-3/4" Slot/gauze 80 Length 10' Set between 39 ft. and 49 ft. Gravel pack? Yes Size range of material 1/2" - 1/4"	
Yellow clay				48		52		11. Static water level: mo./day/yr. 35 ft. below land surface Date 9-23-77	
Shale				52		54		12. Pumping level below land surfaces: 42 ft. after 5 hrs. pumping 125 g.p.m. 47 ft. after 10 hrs. pumping 165 g.p.m. Estimated maximum yield 165 g.p.m.	
								13. Water sample submitted: mo./day/yr. Yes X No Date	
								14. Well head completion: X Pitless adapter 24 inches above grade	
								15. Well grouted? Yes With: Neat cement Bentonite X Concrete Depth: From 5 ft. to 25 ft.	
								16. Nearest source of possible contamination: N/A ft. Direction Type Well disinfected upon completion? X Yes	
								17. Pump: Manufacturer's name Peerless Nat installed Model number 410 HP 10 Volts 440 Length of drop pipe 40 ft. capacity 80 g.p.m. Type: X Submersible Turbine Jet Reciprocating Centrifugal Other	
								18. Elevation:	
								19. Remarks:	
								20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name Address Box A, Garden City, KS Signed [Signature] Date 9-16-78 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5