


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Ness</u>	Fraction <u>1/4 SE 1/4 SW 1/4</u>	Section number <u>15</u>	Township number <u>X 16</u>	Range number <u>(S) R 24 XW</u>
2. Distance and direction from nearest town or city: <u>From north side of</u> <u>Ransom, 1W, 1N, 1/4W</u> Street address of well location if in city:			3. Owner of well: <u>City of Ransom</u> R.R. or street: <u>City Clerk's Office</u> City, state, zip code: <u>Ransom, KS 67572</u>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date <u>6-15-78</u> Well depth <u>60</u> ft.		
				7. <u> </u> Cable tool <u> </u> Rotary <u> </u> Driven <u> </u> Dug <u> </u> Hollow rod <u> </u> Jetted <u> </u> Bored <u>X</u> Reverse rotary		
				8. Use: <u> </u> Domestic <u>X</u> Public supply <u> </u> Industry <u> </u> Irrigation <u> </u> Air conditioning <u> </u> Stock <u> </u> Lawn <u> </u> Oil field water <u> </u> Other		
5. Type and color of material		From	To	9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below Threaded <u> </u> Welded <u>X</u> Surface <u>24</u> in. RMP <u> </u> PVC <u> </u> Weight <u>43.77</u> lbs./ft. Dia. <u>12-3/4</u> in. ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gauge No. <u>330</u>		
Top soil		0	1	10. Screen: Manufacturer's name <u>Johnson</u> Type <u>Irrigator</u> Dia. <u>12-3/4</u> " Slot/gauze <u>80</u> Length <u>10</u> " Set between <u>47</u> ft. and <u>57</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>Yes</u> Size range of material <u>1/4" - 1/2"</u>		
Brown clay		1	8	11. Static water level: <u>41</u> ft. below land surface Date <u>9-16-77</u> mo./day/yr.		
Fine to med. sand and gravel, clay streak		8	13	12. Pumping level below land surfaces: <u>55</u> ft. after <u>8</u> hrs. pumping <u>80</u> g.p.m. <u>52</u> ft. after <u>4</u> hrs. pumping <u>60</u> g.p.m. Estimated maximum yield <u>80</u> g.p.m.		
Fine to med. sand and gravel, loose		13	33	13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <u>X</u> No Date <u> </u>		
Brown sandy clay		33	41	14. Well head completion: <u>X</u> Pitless adapter <u>24</u> inches above grade		
Fine to med. sand and gravel, loose		41	57	15. Well grouted? <u>Yes</u> With: <u> </u> Neat cement <u> </u> Bentonite <u>X</u> Concrete Depth: From <u>5</u> ft. to <u>25</u> ft.		
Yellow clay		57	68	16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <u>X</u> Yes <u> </u> No		
Shale		68	69	17. Pump: <u> </u> Not installed Manufacturer's name <u>Peerless</u> Model number <u>410'S</u> HP <u>5</u> Volts <u> </u> Length of drop pipe <u>56</u> ft. capacity <u>50</u> g.p.m. Type: <u>X</u> Submersible <u> </u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other		
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter-Wilson Drlg. Co. 208</u> Business name <u>P.O. Box A</u> License No. <u> </u> Address <u> </u> Signed <u> </u> Date <u>6-16-78</u> Authorized representative			
Topography: <u> </u> Hill <u>X</u> Slope <u> </u> Upland <u> </u> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5