

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ness	Fraction c 1/4 ne 1/4 ne 1/4	Section number 32	Township number 16	Range number 24	
2. Distance and direction from nearest town or city: 3 miles west-1 south of Ransom, Ks.				3. Owner of well: Ron Horchem R.R. or street: Ransom, Ks. 67572 City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date _____ Well depth 750 ft. 2-5-77			
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material		8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		9. Casing: Material pvc Height: above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 160 lbs./ft. Dia. 5 in. to 750 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 214			
top soil		10. Screen: Manufacturer's name R & B Peckless		Type pvc Dia. 5 Slot/gauze 1/16 Length 57 Set between 693 ft. and 750 ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4-#2			
Clay		11. Static water level: _____ mo./day/yr. 350 ft. below land surface Date 2-5-77		12. Pumping level below land surfaces: 370 ft. after 1 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 100 g.p.m.			
Fine sand		13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 2-5-77		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade			
Shale		15. Well grouted? <input checked="" type="checkbox"/> With: _____ Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		16. Nearest source of possible contamination: ft. 140 Direction west Type old well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Shale and sand rock		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. _____ Address Great Bend, Ks. Signed Fredera Nader Date 3/9 Authorized representative			
Soft clay		18. Elevation:		19. Remarks: Old well pulled and plugged with gravel pack and well cuttings. MNC (refaceous well) 1526612 12 1473 (Use a second sheet if needed)			
Fire clay		Topography: _____ Hill _____ Slope <input checked="" type="checkbox"/> Upland _____ Valley					
Good sand rock							
Hard shale							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5