

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

SCOTT CITY
1:250,000

Kansas Department of Health and Environment
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BCE

1. Location of well:		County Ness	Fraction NW 1/4 SW 1/4 NW 1/4	Section number 19	Township number T 16 S R 25 E/W	Range number
2. Distance and direction from nearest town or city: 1 1/2 miles east 1/2 miles north of Utica, Ks. Street address of well location if in city:			3. Owner of well: John Horacek R.R. or street: Utica, Kansas 67584 City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 11 in. Completion date _____ Well depth 80 ft. 10-1-79	
					7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
top soil		0	3	9. Casing: Material PVC Height: Above ground _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia 5 1/2 to 80 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 258		
hard clay		3	20	10. Screen: Manufacturer's name _____ certain teed Type _____ Dia. 5 1/2 Slot/gauge 1/16 Length 20 Set between _____ ft. and _____ ft. _____ ft. and _____ ft.		
sandy clay		20	31	Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4-3/8-1/2		
clay		31	58	11. Static water level: _____ mo./day/yr. 58 ft. below land surface Date 10-1-79		
sand and gravel clay mixed		58	80	12. Pumping level below land surfaces: 58 ft. after 1 hrs. pumping 20 m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 10-1-79		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 60 Direction south Type cattle pen Well disinfected upon completion? HTH Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name _____ License No. _____ Address Box 713 Great Bend, Ks Signed Fredia Redson Date 10/15/79 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		2600 2520				

T
R
Sec
1/4
1/4
1/4
1/4

16
250
19 NW Sec 19

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5