## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Woter well Contractors) Topeka, Kansas 66620

	County	Fraction	Section		number	Township number	Range number
. Location of well:	Lane	SE 1/4 SE 1/4 NE			27	T 16 S	R 29 5
. Distance and direc	ction from nearest town or city: $8  m N$ ,	22E, 2½N of	3. Owner		Ja	sper Farms, Inc	•
Teet address of well	location if in city: Scott	City, KS	R.R. or st		ode: Cla	lelds, KS 67874	
. Locate with "X" i	a rection below:	Sketch map:	City, sid	10, 21p c	out. Sn	6. Bore hole dia. 26_ in	. Completion date
. Locale will X 1		rectal map.			Ĺ	Well depth 135_ft.	_3-10-76
~~ · · · · · · · · · · · · · · · · · ·						7 Cable tool Rotary	
W Feedboth L Xwell					$n \mid$		Bored X Reverse rotary
					$V \mid$	8. Use:DomesticPublic supply Industry	
					`		
1 <del>1 M</del>			т	-		Dia. 16 in. to 135 ft. der	th Wall Thickness; jaches or
Type and color of	material.	The second secon	.oud	From	То	Dia in. to ft. dep  10. Screen: Manufacturer's i	
433	en language and a supplier of the supplier of	The second secon	e - 10	_	<u></u>	John	son
Clay		Service American Conference Confe		0	25	Type Galv Steel	Dia16 in _ Length30 ft
Sdy clay	7			25	55	Set between105	ft. and 135 ft.
Fine sd	vela			55	59	Gravel pack? <b>yes</b> Size ra	andft.
	the same of the sa		1.77			11. Static water level:	mo./day/yr.
Sd-coars	3e	The second of th	7-0	59	100		face Date <u>1-27-76</u>
Clay				100	102	12 Pumping level below land 118 ft. after	d surfaces: hrs. pumping 500 g.p.m.
Sd coarse				102	128	124 ft. after 4	hrs. pumping 570 g.p.m.
						Estimated maximum yield	<u> </u>
Yellow				128		13. Water sample submitted: Yes X No	mo./day/yr.
						14. Well head completion:	
						Pitless adapter	Inches above grade
						1) Well grouted? Bentonite Concrete	
						Depth: From ft. to	_/5_ft.
						16. Negrest source of possible ft	e contamination: Feed Lot
						Well disinfected upon compl	
						17. Pump:	Not installed ern Land Roller
						Manufacturer's name <b>West</b> Model number	HP Volts
						Length of drop pipe 125	ft. capacity <u>570</u> g.p.m.
						Type: Submersible	X Turbine
						Jet	Reciprocating
	(Use a second s	heet if needed)			L	Centrifugal	Other
B. Elevation:	19. Remarks:					20. Water well contractor's This well was drilled under n	L L
·						is true to the best of my know	- I -
opography: Hill						Weishaar Dril	License No.
Slope						Address Cott	KS 67871
X Uplond Valley						Signa Authorized re	Pate Bate 76
							· · · · · · · · · · · · · · · · · · ·