


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Saline	Township name Smoky View	Fraction NE 1/4	Section number 12	Town number 16	Range number 3
Distance and direction from nearest town or city: 1/4 mile south Assaria				3 Owner of well: Richard H. Johnson Address: Assaria, Kans. 67416		
Locate with "X" in section below: N  W E S 1 Mile				Sketch map:		
2				4 Well depth: 63 ft. Date of completion 6/29/75 Well diameter 8 in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
From To				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
Top soil				7 Casing: Material PVC RMP Height: above *** Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. Diam. 5 1/2 in. Weight 200 lbs./ft. 0 in. to 63 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Silt				8 Screen: Manufacturer Western Plastics Type PVC RMP Dia. 5 1/2 in. Slot 3/32 Length 2 1/2 ft. Set between 54 ft. and 63 ft. Fittings: 1/16 to 3/8 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material		
Brown clay				9 Static water level: 28 ft. below land surface Date 6/19/75		
Blue mud				10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 40 g.p.m.		
Fine sand				11 Water sample submitted: capped <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Coarse sand				12 Well head completion: capped <input type="checkbox"/> Pitless adapter 18 inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: none ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(use a second sheet if needed)						
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rader Drilling Co. 194 Business name License No. 67429 Address Carlton, Kans. Signed Grant E. Rader Date 7-24-75 Authorized representative		