

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County SALINE	Township name SE NE SE	Fraction 26	Section number 16S	Range number 3W
Distance and direction from nearest town or city:			3 Owner of well: Stuart Prather		
Street address of well location if in city:			Address: Bridgeport Ks		
Locate with "X" in section below:		Sketch map:		4 Well depth: 58 ft. Date of completion 7-2-75	
		Well diameter _____ in. 5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry	
				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
2 Type and color of material		From To		7 Casing: Material RMP Height: above below	
				Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. _____ Weight _____ lbs./ft. 4 in. to 58 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No _____ in. to _____ ft. depth	
Alluvium: Clay + silt, gray + buff		0 33		8 Screen:	
				Manufacturer Senp Type RMP Dia. 4 Slot/gauze 3/32 Length 3' Set between 55 ft. and 58 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4"	
Sand fine, some gravel, fine + silt		33 43		9 Static water level:	
				20.5 ft. below land surface Date 7-2-75	
Clay, light blue-gray + sand fine-coarse		43 48		10 Pumping level below land surfaces:	
				_____ ft. after 1/2 hrs. pumping 10 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.	
Gravel, fine to coarse + sand		48 58		11 Water sample submitted:	
				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
(use a second sheet if needed)		12 Well head completion:		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				<input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 3 ft. to 13 ft.	
16 Remarks: elevation		14 Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		15 Pump:	
				<input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hydromatic Drilling 126 Business name _____ License No. _____ Address Salina, KS Signed D. J. Faust Date 7-25-75 Authorized representative			