

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

*Jo BWS
2-14-80*

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Lane	Fraction SW 1/4 SE 1/4 SE 1/4	Section number 34	Township number T 16 S R	Range number 30 EW
2. Distance and direction from nearest town or city: 1N, 1/4 W of			3. Owner of well: City of Healy			
Street address of well location if in city: Healy, Kansas			R.R. or street: City, state, zip code: Healy, KS 67850			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>24</u> in. Completion date _____ Well depth <u>174</u> ft. <u>2-26-77</u>	
		<p style="text-align: center;"><i>Well</i> <i>↓ 1/2 mi.</i> <i>Sewer Line</i></p>			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	19	9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>36</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>43.77</u> lbs./ft. Dia. <u>2</u> in. to <u>174</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>.330</u>		
Gyp		19	29	10. Screen: Manufacturer's name _____ <u>Cook</u> Type <u>Stainless Steel</u> Dia. <u>12 in.</u> <u>100</u> gauze Length <u>30 ft.</u> Set between <u>144</u> ft. and <u>174</u> ft. _____ ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>1/2 down</u>		
Clay 'sdy'		29	47	11. Static water level: _____ mo./day/yr. <u>114</u> ft. below land surface Date <u>3-2-76</u>		
Fine sd clay		47	52	12. Pumping level below land surfaces: <u>138</u> ft. after <u>4</u> hrs. pumping <u>300</u> g.p.m. <u>152</u> ft. after <u>4</u> hrs. pumping <u>400</u> g.p.m. Estimated maximum yield <u>400</u> g.p.m.		
Sd coarse		52	63	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
Fine sd clay		63	73	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>36</u> inches above grade		
Sd coarse		73	78	15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>20</u> ft.		
Fine sd clay		78	112	16. Nearest source of possible contamination: <u>Sewer</u> ft. <u>2640</u> Direction <u>South</u> Type <u>Line</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sd coarse		112	116	17. Pump: _____ Not installed Manufacturer's name <u>Western Land Roller</u> Model number <u>GE</u> HP <u>40</u> Volts <u>460</u> Length of drop pipe <u>160</u> ft. capacity <u>400</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sd fine med 'good'		116	128	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name _____ License No. _____ Address <u>Scott City, KS 67871</u> Signed _____ Date <u>3-29-77</u> Authorized representative _____		
Sd coarse		128	140			
Fine sd good		140	155			
Sd coarse		155	166			
Yellow		166	171			
Shale (Use a second sheet if needed)		171	177			
18. Elevation:	19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

176 300W 34 SUSSE 1/4 1/4 1/4