

48848

To BWS
2-14-80

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Lane	Fraction SW 1/4 SE 1/4	Section number 34	Township number T 16 S	Range number R 30 EW
2. Distance and direction from nearest town or city: Street address of well location if in city:	1/2 N of Healy, KS		3. Owner of well: City of Healy R.R. or street: City, state, zip code: Healy, KS 67850		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. <u>24</u> in. Completion date <u>5-22-76</u> Well depth <u>174</u> ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material <u>Steel</u> Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>30</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>41.51</u> lbs./ft. Dia. <u>12</u> in. to <u>174</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gauge No. <u>312</u>		
5. Type and color of material	From	To	10. Screens: Manufacturer's name Cook Type <u>Stainless Steel</u> <u>12</u> in. gauge <u>.125</u> Length <u>30</u> ft. Set between <u>144</u> ft. and <u>174</u> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>1/2-1/4</u>		
Clay	0	19	11. Static water level: <u>114</u> ft. below land surface Date <u>3-2-76</u>		
Gyp	29	29	12. Pumping level below land surfaces: <u>152</u> ft. after <u>8</u> hrs. pumping <u>400</u> g.p.m. ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>400</u> g.p.m.		
Clay sdy	29	47	13. Water sample submitted: <u> </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u>		
Fine sd clay	47	52	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>30</u> inches above grade		
Sd coarse	52	63	15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>20</u> ft.		
Fine sd clay	63	73	16. Nearest source of possible contamination: ft. <u>2640</u> Direction <u>S</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sd coarse	73	78	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Western Land Roller</u> Model number <u>GE</u> HP <u>40</u> Vol <u>460</u> Length of drop pipe <u>160</u> ft. capacity <u>400</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Fine sd clay	78	112	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling <u>232</u> Business name License No. Address <u>Scott 0144, KS 67871</u> Signed <u>[Signature]</u> Authorized representative <u>7-22-76</u>		
Sd coarse	112	116	18. Elevation:		
Fine sd clay	116	128	19. Remarks: 		
Sd coarse	128	140	Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
Sd fine med good	140	155	Forward the white, blue and pink copies to the Department of Health and Environment		
Fine sd good	155	166	Form WWC-5		
Sd coarse	166	171	MI-1023		
Yellow	171	177			
Shale (Use a second sheet if needed)	177				

T 16 S
 R 30 E
 Sec 34
 1/4 1/4 1/4 1/4
 SW SE
 NW NE