

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.


LAKE SCOTT NE

16 31 W 16 E
T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

BBB

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Scott	Township name Michigan	Fraction N/W	Section number 16	Town number 16	Range number 31
Distance and direction from nearest town or city: 8N, 2W of Manning, KS			3 Owner of well: Soloman Scheuerman			
Street address of well location if in city:			Address: Scott City, KS			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: 140 ft. Date of completion 1-9-75 Well diameter 9 in.
			5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well			
			7 Casing: Material Plas. Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 5 in. to 120 ft. depth Weight 1.8 lbs./ft. Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
2 Type and color of material			From	To	8 Screen: Manufacturer Jess & Lowell Type Plastic Dia. 5 Slot/gauze _____ Length _____ Set between 120 ft. and 140 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material #1	
Clay			0	17	9 Static water level: 120 ft. below land surface Date 1-9-75	
Gyp			17	37	10 Pumping level below land surfaces: 130 ft. after 1 hrs. pumping 10 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.	
Fine sd clay			37	108	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Sd coarse			108	130	12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
Yellow			130	140	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 15 ft.	
Shale			140		14 Nearest source of possible contamination: ft. 500 Direction SE Type Barn Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
BROCK 130'					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Red Jacket Model number 100N1 HP 1 Volts 230 Length of drop pipe 130 ft. capacity 10 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(use a second sheet if needed)					16 Remarks: elevation 2927 (TOP)	
16 Remarks: elevation			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signed [Signature] Date 5-29-75 Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5