


LOCATION OF WATER WELL: County: Scott Fraction SW 1/4 SW 1/4 SW 1/4 Section Number 7 Township Number T 16 S Range Number R 33 E W

Distance and direction from nearest town or city street address of well if located within city? From Hwy. 96 & 83 in Scott City - 13 m. north, 5-3/4 m. west to se corner of section - 5,240 ft. west & 60 ft. north

2 WATER WELL OWNER: Virgil M. Stoll
 RR#, St. Address, Box # : 803 Crescent Ave. Board of Agriculture, Division of Water Resources
 City, State, ZIP Code : Scott City, Kansas 67871 Application Number: 7849

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:  4 DEPTH OF COMPLETED WELL: 190 ft. ELEVATION: _____
 Depth(s) Groundwater Encountered 1. _____ ft. 2. _____ ft. 3. _____ ft.
 WELL'S STATIC WATER LEVEL: 164 ft. below land surface measured on mo/day/yr 10-17-97
 Pump test data: Well water was _____ ft. after _____ hours pumping _____ gpm
 Est. Yield _____ gpm: Well water was _____ ft. after _____ hours pumping _____ gpm
 Bore Hole Diameter: 30 in. to 190 ft., and _____ in. to _____ ft.
 WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well
 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well
 Was a chemical/bacteriological sample submitted to Department? Yes _____ No X; If yes, mo/day/yr sample was submitted _____
 Water Well Disinfected? Yes _____ No X

5 TYPE OF BLANK CASING USED: 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued _____ Clamped _____
 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded X
 2 PVC 4 ABS 7 Fiberglass Threaded _____
 Blank casing diameter: 16 in. to 165 ft., Dia _____ in. to _____ ft., Dia _____ in. to _____ ft.
 Casing height above land surface: 12 in., weight 42.05 lbs./ft. Wall thickness or gauge No. .250
 TYPE OF SCREEN OR PERFORATION MATERIAL: 7 PVC 10 Asbestos-cement
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify) _____
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)
 SCREEN OR PERFORATION OPENINGS ARE: 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes
 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify) _____
 SCREEN-PERFORATED INTERVALS: From 165 ft. to 190 ft., From _____ ft. to _____ ft.
 From _____ ft. to _____ ft., From _____ ft. to _____ ft.
 GRAVEL PACK INTERVALS: From 20 ft. to 190 ft., From _____ ft. to _____ ft.
 From _____ ft. to _____ ft., From _____ ft. to _____ ft.

6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other _____
 Grout Intervals: From 0 ft. to 20 ft., From _____ ft. to _____ ft., From _____ ft. to _____ ft.
 What is the nearest source of possible contamination: 10 Livestock pens 14 Abandoned water well
 1 Septic tank 4 Lateral lines 7 Pit privy 11 Fuel storage 15 Oil well/Gas well
 2 Sewer lines 5 Cess pool 8 Sewage lagoon 12 Fertilizer storage 16 Other (specify below)
 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 13 Insecticide storage _____
 Direction from well? north How many feet? 100

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
		See attached log			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 11/8/97 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 208. This Water Well Record was completed on (mo/day/yr) 11/10/97 under the business name of Minter-Wilson Drilling Co., Inc. by (signature) Nora Keller

INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Topeka, Kansas 66620-0001. Telephone: 913-296-5545. Send one to WATER WELL OWNER and retain one for your records.

1
164 STATIC


TEST HOLE REPORT
MIDWEST WELL & PUMP INC
BOX 692
GARDEN CITY, KS. 67846
316/275-1920

Contract name: Virgil Stoll
803 Crescent
Scott City, Ks. 67871

Test hole: 97-1
Date: 10-17-97
Driller: Soukup

Location: SW of the SW of the SW-1/4 Sec. 7, T16S, R33W, Scott Co.
89' south of existing irrigation well

<u>From</u>	<u>To</u>	<u>Description of Strata</u>
0	1	top soil
1	30	brown clay
30	44	gypsum & brown clay
44	46	fine sand
46	75	gypsum & brown clay
75	81	brown clay
81	102	brown clay, few cemented sand streaks
102	112	fine sand, few clay streaks
112	122	brown clay with cemented sand streaks
122	133	fine sand, cemented with clay streaks
133	142	fine sand, trace of clay
142	162	fine to medium sand, few clay streaks
162	171	medium to coarse sand, small gravel
171	178'6"	coarse sand & gravel
178'6"	188	yellow soapstone
188	189	black shale

 ~~WALTER SUPPLY~~