

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Scott	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 8	Township number T 16 S R 33	Range number 33		
2. Distance and direction from nearest town or city: 1 1/2 N, 5W, 1N, 1/2 E			3. Owner of well: Geo. Epler				
Street address of well location if in city: of Scott City, KS			R.R. or street: 909 Court				
			City, state, zip code: Scott City, KS 67871				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date _____			
				Well depth 174 ft. 6-28-76			
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
						9. Casing: Material Steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP _____ PVC _____ Weight 31.67 lbs./ft. Dia. 16 in. to 174 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .188	
Clay		0		28		10. Screen: Manufacturer's name _____ Free Flow	
Gyp		28		59		Type Prime Steel Dia. 16 in. <input checked="" type="checkbox"/> Gauze 125 Length 20 ft. Set between 154 ft. and 174 ft. _____ ft. and _____ ft.	
Sd coarse		59		68		Gravel pack? yes Size range of material 3/4-1/4	
Sdy clay		68		87		11. Static water level: _____ mo./day/yr. 151 ft. below land surface Date 6-28-76	
Sd coarse		87		96		12. Pumping level below land surfaces: 167 ft. after 8 hrs. pumping 150 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 150 g.p.m.	
Sd rock		96		100		13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
Sd coarse		100		105		14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade	
Clay sdy		105		111		15. Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Fine sd clay		111		159		16. Nearest source of possible contamination: ft. 7920 Direction S Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Sd coarse		159		168		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Clay yellow		168		173		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signed _____ Date 7-22-76 Authorized Representative	
Shale		173		175			
18. Elevation:		19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		(Use a second sheet if needed)					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5