

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Scott	Fraction N/E 1/4 S/W 1/4 S/W 1/4	Section number 17	Township number T 16 S R 33 #/W	Range number
2. Distance and direction from nearest town or city: 12 N., 4 1/2 W. of Scott City, Kansas Street address of well location if in city:			3. Owner of well: Beach Farms R.R. or street: Box 706 City, state, zip code: Scott City, Kansas 67871		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date _____ Well depth <u>125</u> ft. <u>3/26/1979</u>	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <u>Plastic</u> Weight: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>105</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gauge No. <u>250</u>	
				10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5</u> " Slot/gauze <u>1/16</u> Length <u>20</u> ' Set between <u>105</u> ft. and <u>125</u> ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material <u>4 X 1/8</u> "	
				11. Static water level: _____ mo./day/yr. <u>98</u> ft. below land surface Date <u>3-12-79</u>	
				12. Pumping level below land surfaces: <u>110</u> ft. after <u>4</u> hrs. pumping <u>10</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>10</u> g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> Inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.	
				16. Nearest source of possible contamination: ft. <u>4000</u> Direction <u>S/W</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: _____ Not installed Manufacturer's name <u>Gould</u> Model number <u>EJ</u> HP <u>3/4</u> Volts <u>230</u> Length of drop pipe <u>120</u> ft. capacity <u>10</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling & Sup. 232 Business name License No. _____ Address <u>Scott City, KS 67871</u> Signature <u>[Signature]</u> Date <u>3/27/79</u> Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5