

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.


LAKE McBRIDE

1 6 3 3 4 2 9 A
T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

ACC

1 Location of well:	County Scott	Township name Beaver SW SW N/E	Fraction	Section number 24	Town number 16	Range number 33		
Distance and direction from nearest town or city: 1 1/2 N of Scott City, KS			3 Owner of well: Ron Riner					
Street address of well location if in city:			Address: Scott City, KS					
Locate with "X" in section below: N  W X E S 1 Mile			Sketch map:			4 Well depth: 95 ft. Date of completion 3-6-75 Well diameter 9 in.		
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			Clay		0	10	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
			Sd coarse		10	31	7 Casing: Material Plas Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 5 in. to 75 ft. depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 5 in. to 75 ft. depth!	
			Sdy clay		31	37	8 Screen: Manufacturer Jess & Lowell Type Plastic Dia. 5 Slot/gauze _____ Length _____ Set between 75 ft. and 95 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material #1	
			Sd coarse		37	55	9 Static water level: 26 ft. below land surface Date 3-6-75	
			Sd rock H 8		55	57	10 Pumping level below land surfaces: 36 ft. after 1 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.	
			Fine sd clay		57	79	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
			Sd coarse		79	92	12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
			Rock		92	93	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 15 ft.	
			Yellow		93	95	14 Nearest source of possible contamination: ft. 500 Direction S Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
(use a second sheet if needed)					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Red Jacket Model number 100N1 HP 1 Volts 230 Length of drop pipe 85 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signed <i>[Signature]</i> Date 5-29-75 Authorized representative			
16 Remarks: elevation 2895 (TOPO)								
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley								

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5