

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction SW 1/4 SE 1/4 SE 1/4	Section number 24	Township number T 16 S R 33	Range number 33	EW
2. Distance and direction from nearest town or city: 11N of Street address of well location if in city: Scott City, KS			3. Owner of well: Don Christy R.R. or street: Box 278 City, state, zip code: Scott City, KS 67871				
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>81</u> ft. <u>8-12-75</u>		
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <u>Steel</u> Height (Above) or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP _____ PVC _____ Weight <u>31.67</u> lbs./ft. Dia. <u>16</u> in. to <u>81</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>188</u>			
Clay		0	62	10. Screen: Manufacturer's name _____ Free Flow Type <u>Prime Steel</u> Dia. <u>16 in.</u> Slot/gauze <u>.125</u> Length <u>20 ft.</u> Set between <u>61</u> ft. and <u>81</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>3/4-1/4</u>			
Sd coarse		62	71	11. Static water level: _____ mo./day/yr. <u>6</u> ft. below land surface Date <u>5-27-75</u>			
Clay		71	78	12. Pumping level below land surfaces: <u>70</u> ft. after <u>4</u> hrs. pumping <u>550</u> g.p.m. <u>71</u> ft. after <u>4</u> hrs. pumping <u>560</u> g.p.m. Estimated maximum yield <u>560</u> g.p.m.			
Yellow		78	82	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____			
Shale		82	85	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade <input checked="" type="checkbox"/> Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
				16. Nearest source of possible contamination: ft. <u>3960</u> Direction <u>W</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: _____ Not installed Manufacturer's name <u>Western Land Roller</u> Model number <u>GR</u> HP <u>15</u> Volts <u>480</u> Length of drop pipe <u>70</u> ft. capacity <u>560</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling <u>232</u> Business name _____ License No. _____ Address <u>Scott City, KS 67871</u> Signed <u>Don Christy</u> Date <u>7-20-76</u> Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5