

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 24	Township number T 16 S R 33	Range number E/W
2. Distance and direction from nearest town or city: 1 1/4 N of Street address of well location if in city: Scott City, KS			3. Owner of well: Don Christy R.R. or street: Box 278 City, state, zip code: Scott City, KS 67871			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>71</u> ft. <u>8-12-75</u>		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	47	9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP _____ PVC _____ Weight <u>31.67</u> lbs./ft. Dia. <u>16</u> in. to <u>71</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>.188</u>		
Fine sd clay		47	55	10. Screen: Manufacturer's name _____ <u>Free Flow</u> Type <u>Prime Steel</u> Dia. <u>16 in.</u> Clo/gauze <u>.125</u> Length <u>20 ft.</u> Set between <u>51</u> ft. and <u>71</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>3/4-1/4</u> ft.		
Sd coarse		55	67	11. Static water level: <u>6 1/2</u> ft. below land surface Date <u>6-4-75</u> mo./day/yr.		
Clay yellow		67	76	12. Pumping level below land surfaces: <u>52</u> ft. after <u>4</u> hrs. pumping <u>310</u> g.p.m. <u>63</u> ft. after <u>4</u> hrs. pumping <u>400</u> g.p.m. Estimated maximum yield <u>400</u> g.p.m.		
Shale		76	80	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
				15. Well grouted? <input type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: ft. <u>5280</u> Direction <u>W</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name <u>Western Land Roller</u> Model number <u>CE</u> HP <u>10</u> Volts <u>480</u> Length of drop pipe <u>60</u> ft. capacity <u>400</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name License No. Address: <u>Scott City, KS 67871</u> Signature: _____ Date: <u>7-20-76</u> Authorized representative		
18. Elevation:		(Use a second sheet if needed)				
19. Remarks:						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5