

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Scott	Fraction SW 1/4 SE 1/4 NE 1/4	Section number 24	Township number T 16 S R 34 E/W	Range number
2. Distance and direction from nearest town or city: 12N, 6W, 1/2S of			3. Owner of well: Roy Fairleigh		
Street address of well location if in city: Scott City, KS			R.R. or street: Box 86 - RFD #3		
			City, state, zip code: Scott City, KS 67871		
4. Locate with "X" in section below:			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 26 in. Completion date _____ Well depth 204 ft. 3-19-76
Clay			0	38	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Gyp			38	51	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Clay			51	57	9. Casing: Material Steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP _____ PVC _____ Weight 31.67 lbs./ft. Dia. 16 in. to 204 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. 188
Sd			57	59	10. Screen: Manufacturer's name Johnson & Free Flow Type Galv. & Prime Steel Dia. 16 in. <input checked="" type="checkbox"/> Gauze 100 & 125 Length 32 ft. Set between 172 ft. and 204 ft. Gravel pack? yes Size range of material 3/4-1/2 ft.
Clay			59	69	11. Static water level: _____ mo./day/yr. 161 ft. below land surface Date 12-3-75
Fine sd clay			69	108	12. Pumping level below land surfaces: NA _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
Sd rock			108	115	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____
Fine sd clay			115	120	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade
Sd med			120	130	15. Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.
Fine sd clay			130	178	16. Nearest source of possible contamination: ft. 2040 Direction SW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____
Sd coarse			178	192	17. Pump: _____ Not installed Manufacturer's name Layne & Bowler Model number _____ HP _____ Volts _____ Length of drop pipe 190 ft. capacity NA g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Clay yellow			192	197	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address: Scott City, KS 67871 Signed: <i>[Signature]</i> Date 7-20-76 Authorized representative
Shale			197	200	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5