


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Wichita	Fraction NW 1/4 NW 1/4 SE 1/4	Section number 1	Township number T 16 S R 35 E	Range number 35
2. Distance and direction from nearest town or city: 12W, 14 1/2 N, 1/2 W of		3. Owner of well: Paul Hillery			
Street address of well location if in city: Scott City, Kansas		R.R. or street: 604 Madison			
		City, state, zip code: Scott City, KS 67871			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 3-30-77	
				Well depth 107 ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material Plas. Height: Above or below Threading Glue Surface 12 in. RMP <input checked="" type="checkbox"/> PVC Weight 1.8 lbs./ft. Dia. 5 in. to 87 ft. depth Wall Thickness: inches or Dia. 5 in. to 87 ft. depth gage No. 250	
5. Type and color of material		From	To	10. Screen: Manufacturer's name Jess & Lowell	
Clay		0	5	Type RMP Dia. 5 in.	
Gyp		5	31	Slotted gauge 1/16 Length 10 ft.	
Fine sd		31	45	Set between 87 ft. and 107 ft.	
Fine sd clay		45	65	Gravel pack? yes Size range of material 1/4-1/8	
Sd coarse		65	76	11. Static water level: 91 ft. below land surface Date 3-30-77	
Clay		76	82	12. Pumping level below land surfaces: NA	
Fine sd clay		82	88	____ ft. after ____ hrs. pumping ____ g.p.m.	
Sd coarse		88	100	____ ft. after ____ hrs. pumping ____ g.p.m.	
Clay yellow		100	110	Estimated maximum yield ____ g.p.m.	
Shale		110		13. Water sample submitted: ____ mo./day/yr.	
				Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____	
				14. Well head completion: 12 inches above grade	
				____ Pitless adapter	
				15. Well grouted? yes	
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete	
				Depth: From 0 ft. to 15 ft.	
				16. Nearest source of possible contamination: Septic	
				ft. 1320 Direction South Type Septic	
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed	
				Manufacturer's name ____	
				Model number ____ HP ____ Volts ____	
				Length of drop pipe ____ ft. capacity ____ g.p.m.	
				Type:	
				<input type="checkbox"/> Submersible <input type="checkbox"/> Turbine	
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography:			This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
<input type="checkbox"/> Hill			Weishaar Drilling 232		
<input checked="" type="checkbox"/> Slope			Business name License No.		
<input type="checkbox"/> Upland			Address Scott City, KS 67871		
<input type="checkbox"/> Valley			Signed [Signature] Authorized representative 3-31-77		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5