


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Wichita	Fraction SE 1/4 SW 1/4 NW 1/4	Section number 4	Township number T 16 S R 35 E	Range number 35 E
2. Distance and direction from nearest town or city: 12W, 12N, 2W, 2N,		3. Owner of well: R.R. or street: City, state, zip code:		Conrad Kough RFD #3 - Box 61 Scott City, KS 67871	
Street address of well location if in city: 1NW, 1W, 1/4 S of Scott City					
4. Locate with "X" in section below:		Sketch map:			
					
5. Type and color of material		From	To	6. Bore hole dia. 26 in. Completion date 12-6-74 Well depth 134 ft.	
Clay		0	20	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Gyp		20	40	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>	
Sd coarse		40	51	9. Casing: Material Steel Height: 10 ft. or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.67 lbs./ft. Dia. 16 in. to 134 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .188	
Sd rock H		51	57	10. Screen: Manufacturer's name Johnson Type Calv. Steel Dia. 16 in. Slot gauge 100 Length 20 ft. Set between 114 ft. and 134 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 3/4-1/2	
Sd coarse		57	67	11. Static water level: <input type="checkbox"/> mo./day/yr. 100 ft. below land surface Date 9-24-74	
Clay		67	74	12. Pumping level below land surfaces: 121 ft. after 4 hrs. pumping 510 g.p.m. 123 ft. after 4 hrs. pumping 540 g.p.m. Estimated maximum yield 540 g.p.m.	
Fine sd clay		74	85	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
Clay		85	92	14. Well head completion: Pitless adapter 12 inches above grade	
Sd coarse		92	99	15. Well grouted? <input checked="" type="checkbox"/> With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.	
Clay		99	105	16. Nearest source of possible contamination: ft. 2640 Direction E Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Sd coarse		105	128	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Western Land Roller Model number GE HP 30 Volts 440 Length of drop pipe 120 ft. capacity 540 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Yellow		128	130	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name Scott City, KS 67871 License No. 232 Address Scott City, KS 67871 Signature [Signature] Date 7-17-76 Authorized representative	
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5