

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County <u>Wichita</u>	Fraction <u>SW 1/4 SW 1/4 NW 1/4</u>	Section number <u>4</u>	Township number <u>T 16 S R 35 E</u>	Range number <u>W</u>
2. Distance and direction from nearest town or city: <u>12W, 12N, 2W, 2N,</u> Street address of well location if in city <u>2W, 1/2N of Scott City, KS</u>		3. Owner of well: <u>Conrad Kough</u> R.R. or street: <u>RFD #3 - Box 61</u> City, state, zip code: <u>Scott City, KS 67871</u>			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile		Sketch map: <u>3/4 mi. X well - Septic</u>		6. Bore hole dia. <u>26</u> in. Completion date <u>12-5-74</u> Well depth <u>132</u> ft.	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Clay		0	25	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Gyp		25	38	9. Casing: Material <u>Steel</u> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>31.67</u> lbs./ft. Dia. <u>16</u> in. to <u>132</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>132</u> ft. depth gage No. <u>188</u>	
Clay		38	41	10. Screen: Manufacturer's name <u>Johnson</u> Type <u>Galv. Steel</u> Dia. <u>16</u> in. Slot gauze <u>100</u> Length <u>20</u> ft. Set between <u>112</u> ft. and <u>132</u> ft. ft. and <u>132</u> ft.	
Sdy clay T		41	50	Gravel pack? <u>yes</u> Size range of material <u>3/4-1</u>	
Sd rock		50	60	11. Static water level: <u>100</u> ft. below land surface Date <u>9-21-74</u> mo./day/yr.	
Sd coarse		60	68	12. Pumping level below land surfaces: <u>120</u> ft. after <u>4</u> hrs. pumping <u>400</u> g.p.m. <u>124</u> ft. after <u>4</u> hrs. pumping <u>450</u> g.p.m. Estimated maximum yield <u>450</u> g.p.m.	
Clay		68	85	13. Water sample submitted: <u>100</u> ft. below land surface Date <u>9-21-74</u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
Fine sd clay		85	105	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade	
Sd coarse		105	126	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>12</u> ft.	
Yellow		126		16. Nearest source of possible contamination: ft. <u>3960</u> Direction <u>E</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
(Use a second sheet if needed)				17. Pump: Manufacturer's name <u>Western Land Roller</u> Not installed Model number <u>GE</u> HP <u>25</u> Volts <u>440</u> Length of drop pipe <u>120</u> ft. capacity <u>450</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> 232 Business name License No. Address <u>Scott City, KS 67871</u> Signed <u>[Signature]</u> Date <u>12-7-76</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5