


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Wichita	Fraction SE 1/4 NW 1/4 NW 1/4	Section number 23	Township number T 16 S R 35	Range number 35
2. Distance and direction from nearest town or city: 5 west of Pence, 1/2 south.		3. Owner of well: Melvin Nuss R.R. or street: Lakin & Baker St. City, state, zip code: Great Bend, Ks. 67530			
4. Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. 26 in. Completion date 10-31-75 Well depth 185 ft.	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material steel Height: Above surface Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 186 ft. depth Wall Thickness 1/2 inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250	
				10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/gauge <input type="checkbox"/> Length 20 ft. Set between 160 ft. and 180 ft. Perf: 150-160 ft. and 180-185 ft. Gravel pack? yes Size range of material 1/2" down	
				11. Static water level: 152 ft. below land surface Date 9-29-75 mo./day/yr.	
				12. Pumping level below land surfaces: 175 ft. after 2 hrs. pumping 690 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 690 g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Customer's Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Customer furnished pump.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name Box A Garden City, Ks. License No. <input type="checkbox"/> Signed [Signature] Date 12 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

WILSON DRILLING CO.

INCORPORATED

Drilling
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269

P.O. Box 493

GARDEN CITY, KANSAS 67846

Melvin O. Nuss
Wichita County
7-18-75

Location: 5 miles west of Pence, $\frac{1}{2}$ mile south
NW $\frac{1}{4}$ 23-16-35

Test #1

0	4	Top soil
4	18	Brown clay
18	27	Brown sandy clay
27	31	Fine to med. sand & gravel
31	52	White rock mixed with brown & white clay (hard)
52	71	Fine to med. sand & gravel mixed with white rock (hard)
71	85	Brown sandy clay
85	97	Brown sandy clay, small streaks fine to med. sand (took water)
97	111	Fine to med. sand & gravel (loose)
111	125	Fine to med. sand, small streaks of clay (tight)
125	135	Fine to med. sand & gravel (loose)
135	155	Fine to med. sand & gravel (tight)
155	166	Fine to med. sand & gravel (little tight)
166	179	Fine to med. sand & gravel (loose)
179	182	Yellow clay
182	185	Shale

Static Water Level: 149