


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

RUSSELL SPRINGS 3NW

CDB

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction NW 1/4 SE 1/4 SW 1/4	Section number 15	Township number T 16 S R 37	Range number 37		
2. Distance and direction from nearest town or city: 12 north, 2 west $\frac{1}{2}$ north of Leoti Street address of well location if in city:			3. Owner of well: Harold Smith R.R. or street: Leoti, KS 67861 City, state, zip code:					
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 			6. Bore hole dia. 26 in. Completion date 7-30-76 Well depth 191 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.8 lbs./ft. Dia. 16 in. to 192 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>			10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot/gauze <input type="checkbox"/> Length 20' Set between 160 ft. and 180 ft. Perf: 140-160 and 180-191 ft. Gravel pack? yes size range of material 1/2" Down		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 129 below land surface Date 7-27-76			12. Pumping level below land surfaces: 172 ft. after 3 hrs. pumping 550 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 550 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			16. Nearest source of possible contamination: Field N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Field mic Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goolds U.S. Pumps Model number 175LC HP 100 Volts <input type="checkbox"/> Length of drop pipe 180 ft. capacity 500 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 20 Business name License No. <input type="checkbox"/> Address Box A Garden City, KS 67846 Signed [Signature] Date 2-24-77 Authorized representative		
			18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

16 370 15 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Harold M. Smidt
Wichita County
6-11-76

Location: From Test #1 go south 2½ telephone poles
SW¼ 15-16-37

Test #2

0	5	Top soil
5	16	Brown clay
16		Lost Circulation

Test #3

0	5	Top soil
5	16	Brown clay
16	16	Lost circulation
16	35	Brown clay
35	60	Brown rock, hard pull down
60	80	Fine to med. sand & gravel
80	93	Fine to med. sand & gravel 25% clay
93	112	Brown sandy clay
112	126	Brown sandy clay with sand streak
126	149	Fine to med. sand
149	158	Brown sandy clay
158	173	Fine to med. sand (tight)
173	190	Fine to med. sand, some gravel (tight)
190	198	Yellow clay
198	200	Shale

Static Water Level: 130