

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 28	Township number T 16 S R 37	Range number E 11
2. Distance and direction from nearest town or city: 11N, 3W of			3. Owner of well: Bob Weilert			
Street address of well location if in city: Leoti, KS			R.R. or street: City, state, zip code: Leoti, KS 67861			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 209 ft. 12-7-74		
				7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other		
Clay		0	29	9. Casing: Material Steel Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP ___ PVC ___ Weight 31.67 lbs./ft. Dia. 16 in. to 209 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. 188		
Gyp		29	35	10. Screen: Manufacturer's name Free Flow Type Prime Steel Dia. 16 in. Slot gauze 125 Length 40 ft. Set between 169 ft. and 209 ft. ___ ft. and ___ ft.		
Sd coarse		35	53	Gravel pack? <input checked="" type="checkbox"/> YES Size range of material 3/4-1/2		
Sd rock		53	56	11. Static water level: _____ mo./day/yr. 129 ft. below land surface Date 9-10-74		
Fine sd clay		56	85	12. Pumping level below land surfaces: 162 ft. after 4 hrs. pumping 650 g.p.m. 183 ft. after 4 hrs. pumping 1000 g.p.m. Estimated maximum yield _____ g.p.m.		
Clay		85	115	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No ___ Date _____		
Fine sd clay		115	130	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade		
Sd coarse		130	140	15. Well grouted? <input checked="" type="checkbox"/> With: ___ Neat cement ___ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 2 ft. to 12 ft.		
Fine sd clay		140	145	16. Nearest source of possible contamination: ft. 2640 Direction W Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ___ No ___		
Fine sd		145	152	17. Pump: _____ Not installed Manufacturer's name Western Land Roller Model number GE HP 60 Volts 460 Length of drop pipe 200 ft. capacity 1000 g.p.m. Type: ___ Submersible <input checked="" type="checkbox"/> Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other		
Med sd good		152	167	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signed [Signature] Date 7-17-76 Authorized representative		
Sd rock		167	169			
Fine sd		169	188			
Sd coarse		188	207			
Clay yellow		207	211			
Shale (Use a second sheet if needed)		211	215			
18. Elevation:		19. Remarks:				
Topography: ___ Hill ___ Slope <input checked="" type="checkbox"/> Upland ___ Valley						

L6 320 28 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5