

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DDDD

| | | | | | | |
|---|-----------------------------------|--|---|---|---|---|
| 1. Location of well: | | County Wichita | Fraction SE 1/4 SE 1/4 SE 1/4 | Section number 29 | Township number T 16 S R 37 | Range number 37 |
| 2. Distance and direction from nearest town or city: 1 1/2 north of Leoti | | | 3. Owner of well: Harold Smith R.R. or street: Leoti, KS 67861 City, state, zip code: | | | |
| 4. Locate with "X" in section below: | | Sketch map: | | | 6. Bore hole dia. 26 in. Completion date 8-1-76 Well depth 220 ft. | |
| | | 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary | | | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other | |
| | | | | | 9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 22 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/> | |
| 5. Type and color of material | | | | From | To | 10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot/gauze <input type="checkbox"/> Length 20" Set between 190 ft. and 210 ft. Perf: 140-190 ft. and 210-220 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2" Down |
| | | | | 11. Static water level: 138 ft. below land surface Date 7-31-76 mo./day/yr. | | |
| | | | | 12. Pumping level below land surfaces: 187 ft. after 3 hrs. pumping 800 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 800 g.p.m. | | |
| | | | | 13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/> | | |
| | | | | 14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade | | |
| | | | | 15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. | | |
| | | | | 16. Nearest source of possible contamination: Field N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | |
| | | | | 17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds U.S. Pumps Model number 12 JLC HP 100 Volts <input type="checkbox"/> Length of drop pipe 210 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | | |
| | | | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name License No. Address Box A Garden City, KS Signed [Signature] Date 24-7 Authorized representative | | |
| 18. Elevation: | 19. Remarks: 3391 (711) | | 20. Water well contractor's certification: (Continued) | | | |
| Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley | | | | | | |

16 270 29 SE SE SE
 Sec 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Harold M. Schmidt
Wichita County
6-8-76

Location: Hwy 25 North of Leoti go $\frac{1}{2}$ North of High Plain
School, 4 Miles West, $2\frac{1}{2}$ South, $\frac{1}{2}$ East
SE $\frac{1}{4}$ 29-16-37

Test #1

DDD

RUSSELL SPRINGS 3NW

| | | |
|-----|-----|---|
| 0 | 2 | Top soil |
| 2 | 23 | Brown clay |
| 23 | 36 | Light brown sandy clay |
| 36 | 52 | Brown rock, hard pull down |
| 52 | 58 | Brown sandy clay |
| 58 | 71 | Fine to med. sand & gravel (hard) |
| 71 | 88 | Brown sandy clay |
| 88 | 97 | Brown clay with sand streak |
| 97 | 103 | Fine to med. sand & gravel |
| 103 | 116 | Brown clay |
| 116 | 121 | Fine to med. sand & gravel |
| 121 | 125 | Fine sand (hard) |
| 125 | 134 | Fine to med. sand (tight) |
| 134 | 142 | Brown rock with cemented sandstone (hard) |
| 142 | 156 | Fine to med. sand, 15% clay streak |
| 156 | 171 | Fine to med. sand & gravel |
| 171 | 200 | Fine sand, some med. sand (loose) |
| 200 | 213 | Med. sand to med. coarse gravel (loose) |
| 213 | 216 | Yellow clay |
| 216 | 218 | Shale |

Static Water Level: 131

T.O. 220 XXX

BROCK 213'