


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ACB

1. Location of well:		County Wichita	Fraction NW/4 SW 1/4 NE 1/4	Section number 32	Township number T 16 S R	Range number 37 <i>EW</i>
2. Distance and direction from nearest town or city: 9 north, 2 west 1 1/2 north of Leoti Street address of well location if in city:			3. Owner of well: Harold Smith R.R. or street: Leoti, KS 67861 City, state, zip code:			
4. Locate with "X" in section below: N  W E S 1 Mile			Sketch map:		6. Bore hole dia. 26 in. Completion date 9-10-76 Well depth 215 ft.	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <u>16</u> PVC <input type="checkbox"/> Weight <u>36.8</u> lbs./ft. Dia. <u>16</u> in. to <u>216</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u> </u>	
					10. Screen: Manufacturer's name <u>Johnson</u> Type <u>G.I.V.</u> Dia. <u>16"</u> Slot/gauze <u> </u> Length <u>20'</u> Set between <u>190</u> ft. and <u>210</u> ft. <u>Perf: 140-190</u> and <u>210-215</u> ft. Gravel pack? <u>yes</u> Size range of material <u>2" Down</u>	
					11. Static water level: <u> </u> mo./day/yr. <u>138</u> ft. below land surface Date <u>9-1-76</u>	
					12. Pumping level below land surfaces: <u>193</u> ft. after <u>3</u> hrs. pumping <u>750</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>750</u> g.p.m.	
					13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>	
					14. Well head completion: <u>12</u> <input type="checkbox"/> Pitless adapter <u> </u> Inches above grade	
					15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
					16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u>Field</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: <u>Not installed</u> Manufacturer's name <u>Goulds U.S. Pumps</u> Model number <u>12 JNC</u> HP <u>100</u> g.p.m. Length of drop pipe <u>205</u> ft. capacity <u>700</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			(Use a second sheet if needed)			
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: 3380 (7010)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter Wilson Drilling</u> <u>208</u> Business name License No. Address <u>Box A Garden City, KS 67841</u> Signed <u>[Signature]</u> Date <u>2-24-77</u> Authorized representative		

166-370-32 NW SW NE
T
R
E
S
C
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Wendell • Schmidt
Wichita County
6-10-76

Location: Northeast corner NE 1/4 32-16-37

Test #5

ACB

RUSSELL SPRINGS 35W

0	3	Top soil
3	27	Brown clay
27	43	Brown rock (hard)
43	59	Brown rock mixed with cemented sandstone (hard)
59	67	Brown rock, cemented sandstone, 20% clay
67	88	Brown clay
88	103	Brown clay, trace of sandstreak
103	157	Fine to med. sand, 2% gravel
157	167	Fine to med. sand, 15% gravel (tight)
167	173	Cemented sandstone (hard)
173	200	Fine sand (tight)
200	206	Fine to med. sand & Gravel (tight)
206	213	Med. sand to med. coarse gravel
213	215	Yellow clay
215	216	Shale

Static Water Level: 130

T.P. 215' XXX

BRACK 213'