

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction SW 1/4 SW 1/4 NE 1/4	Section number 2	Township number T 16 S R 38 E/W	Range number 38 E/W
2. Distance and direction from nearest town or city: 1 1/2 N, 6 1/2 W, 1/2 S			3. Owner of well: Harold Brown			
Street address of well location if in city: of Leoti, KS			R.R. or street: City, state, zip code: Leoti, KS 67861			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>148</u> ft. <u>10-8-74</u>		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	25	9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>91.67</u> lbs./ft. Dia. <u>16</u> in. to <u>148</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>188</u>		
Gyp		25	48	10. Screen: Manufacturer's name _____ <u>Free Flow</u> Type <u>Prime Steel</u> Dia. <u>16 in.</u> Slot/gauze <u>.125</u> Length <u>40 ft.</u> Set between <u>108</u> ft. and <u>148</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>3/4-1</u>		
Clay		48	58	11. Static water level: _____ mo./day/yr. <u>102</u> ft. below land surface Date <u>8-20-74</u>		
Sd med		58	70	12. Pumping level below land surfaces: <u>116</u> ft. after <u>4</u> hrs. pumping <u>200</u> g.p.m. <u>126</u> ft. after <u>4</u> hrs. pumping <u>300</u> g.p.m. Estimated maximum yield _____ g.p.m.		
Clay		70	84	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
Fine sd clay		84	89	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
Clay		89	95	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Fine sd clay		95	100	16. Nearest source of possible contamination: ft. <u>2640</u> Direction <u>NW</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sd coarse		100	108	17. Pump: _____ Not installed Manufacturer's name <u>Western Land Roller</u> Model number <u>GE</u> HP <u>20</u> Vol <u>460</u> Length of drop pipe <u>140</u> ft. capacity <u>300</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sd rock		108	110	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name <u>Scott City, KS 67871</u> License No. _____ Address _____ Signature <u>[Signature]</u> Date <u>7-17-76</u> Authorized representative		
Fine sd clay		110	115			
Sd coarse		115	136			
Sd rock		136	137			
Clay yellow		137	150			
Shale		150				
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

16 38 W 2 S SUBSURNE 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5