

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 2	Township number T 16 S R 38 E/W	Range number 38
2. Distance and direction from nearest town or city: 1 1/2 N, 6 1/2 W, 1 S of Leoti, KS			3. Owner of well: Elvin Brown R.R. or street: RFD #4 - #3 Purcell Road City, state, zip code: Manhattan, KS 66502			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 180 ft. 4-4-75		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input checked="" type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	29	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.67 lbs./ft. Dia. 16 in. to 180 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 188		
Gyp H		29	32	10. Screen: Manufacturer's name _____ Free Flow Type Prime Steel Dia. 16 in. Slot gauge 125 Length 40 ft. Set between 140 ft. and 180 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 3/4-1/2		
Clay		32	38	11. Static water level: _____ mo./day/yr. 112 ft. below land surface Date 2-18-75		
Gyp H		38	51	12. Pumping level below land surfaces: 134 ft. after 4 hrs. pumping 500 g.p.m. 145 ft. after 4 hrs. pumping 800 g.p.m. Estimated maximum yield 800 g.p.m.		
Clay		51	59	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Sd coarse		59	92	14. Well head completion: _____ Pitless adapter 12 inches above grade		
Clay		92	101	15. Well grouted? <input checked="" type="checkbox"/> With: Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.		
Sd coarse		101	112	16. Nearest source of possible contamination: ft. 5280 Direction NW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
XXX Fine sd clay		112	128	17. Pump: _____ Not installed Manufacturer's name Western Land Roller Model number GE HP 50 Vol 460 Length of drop pipe 170 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sd coarse		128	135	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ License No. _____ Address Scott City, KS 67871 Signed <i>[Signature]</i> Date 7-19-76 Authorized representative		
Fine sd clay		135	145			
Sd rock		145	150			
Sd coarse		150	175			
Yellow		175	182			
Shale		182	185			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

L 16
 38
 2
 SWSUSE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5