

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 12	Township number T 16 S R 38 E	Range number 38 E
2. Distance and direction from nearest town or city: 12N, 4W, 1N, Street address of well location if in city: 1 1/2 W of Leoti, KS			3. Owner of well: Vise & Honeywell & Richard Hobson R.R. or street: Marienthal, KS 67863 City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 197 ft. 11-19-74		
				7. Cable tool: <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Clay				0	21	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.67 lbs./ft. Dia. 16 in. to 197 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 188
Gyp				21	28	10. Screen: Manufacturer's name _____ Free Flow Type Prime Steel Dia. 16 in. 3/8 gauze 125 Length 40ft. Set between 157 ft. and 197 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 3/4-1/2 ft.
Rock H				28	34	11. Static water level: _____ mo./day/yr. 125 ft. below land surface Date 10-2-74
Gyp				34	56	12. Pumping level below land surfaces: 167 ft. after 4 hrs. pumping 950 g.p.m. 169 ft. after 4 hrs. pumping 970 g.p.m. Estimated maximum yield 970 g.p.m.
Clay sdy				56	97	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
Sd coarse				97	102	14. Well head completion: _____ <input type="checkbox"/> Pitless adapter 12 Inches above grade
Clay sdy				102	112	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Fine sd clay				112	127	16. Nearest source of possible contamination: ft. 2640 Direction S Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Sd coarse				127	140	17. Pump: _____ Not installed Manufacturer's name Layne & Bowler Model number GE HP 50 Volts 440 Length of drop pipe 180 ft. capacity 970 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Clay				140	142	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ License No. _____ Address Scott City, KS 67871 Signed Scott City Date 7-17-76 Authorized representative
Sd rock				142	146	
Clay				146	157	
Fine sd clay				157	166	
Sd rock				166	170	
Sd coarse				170	195	
Yellow (Use a second sheet if needed)				195	200	
18. Elevation:		19. Remarks: Shale		20. Water well contractor's certification: (continued)		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

16 38 E 12
 Sec
 1/4 1/4 1/4
 SUSUSE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5