

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Wichita</b>	Fraction <b>SW 1/4 SW 1/4 SW 1/4</b>	Section number <b>16</b>	Township number <b>T 16 S R 38 E</b>	Range number <b>38 E</b>
2. Distance and direction from nearest town or city: <b>12N of Selkirk, KS</b>			3. Owner of well: <b>Jr. Watt</b>			
Street address of well location if in city:			R.R. or street:			
			City, state, zip code: <b>Leoti, KS 67861</b>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date <u>6-23-76</u> Well depth <u>180</u> ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		0	25	9. Casing: Material <u>Plas.</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Glue Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>160</u> ft. depth; Wall Thickness: inches or Dia. <u>5</u> in. to <u>160</u> ft. depth; gauge No. <u>.250</u>		
Fine sd		25	39	10. Screen: Manufacturer's name <u>Jess &amp; Lowell</u> Type <u>RMP</u> Dia. <u>5 in.</u> <input checked="" type="checkbox"/> slot gauge <u>1/16</u> Length <u>20 ft.</u> Set between <u>160</u> ft. and <u>180</u> ft. <u>180</u> ft. and <u>180</u> ft.		
Clay		39	46	Gravel pack <input checked="" type="checkbox"/> yes Size range of material <u>1/8</u>		
Sd coarse		46	52	11. Static water level: <u>120</u> ft. below land surface Date <u>6-23-76</u> mo./day/yr.		
Clay		52	59	12. Pumping level below land surfaces: <u>130</u> ft. after <u>1</u> hrs. pumping <u>10</u> g.p.m. <u>    </u> ft. after <u>    </u> hrs. pumping <u>    </u> g.p.m. Estimated maximum yield <u>10</u> g.p.m.		
Sdy clay		59	108	13. Water sample submitted: <u>    </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>    </u>		
Sd coarse		108	122	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
Fine sd clay		122	126	15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.		
Sd coarse		126	165	16. Nearest source of possible contamination: ft. <u>30</u> Direction <u>SW</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Fine sd clay		165	171	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Peerless</u> Model number <u>    </u> HP <u>3/4</u> Volts <u>220</u> Length of drop pipe <u>173</u> ft. capacity <u>10</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sd coarse		171	178			
Sdy clay F		178	180			
Yellow		180	190			
Shale		190				
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Weishaar Drilling 232</b> Business name <u>    </u> License No. <u>    </u> Address <u>Scott City, KS 67871</u> Signed <u>    </u> Date <u>7-22-76</u> Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 16  
 R 38 E  
 S 16  
 Sec 16  
 1/4 1/4 1/4 1/4  
 SWSUBD

Forward the white, blue and pink copies to the Department of Health and Environment

Form WW-5