

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Wichita	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 24	Township number T 16 S R 38 E/W	Range number 38 E/W
2. Distance and direction from nearest town or city: Eleven mi N (State 23), six mi W & 1/2 mi N			3. Owner of well: Bernard Baker (Baker Farms)			
Street address of well location if in city: for Leoti.			R.R. or street: City, state, zip code: Leoti, KS 67861			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date _____ Well depth <u>216</u> ft. <u>8-23-77</u>		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Black top soil		0		5		9. Casing: Material _____ Height: Above 5000 _____ Threaded _____ Welded _____ Surface <u>12</u> in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft.
Tan clay		5		45		Dia. <u>5</u> in. to <u>106</u> ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; Gauge No. <u>0.265</u>
Medium sandy clay		45		57		10. Screen: Manufacturer's name <u>J & L, sawed out</u> Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze <u>1/8"</u> Length <u>20'</u> Set between <u>198</u> ft. and <u>216</u> ft. <u>198</u> ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4" down</u>
Altarnate layers of sand and sandy clay		57		156		11. Static water level: _____ mo./day/yr. <u>120</u> ft. below land surface Date <u>8-23-77</u>
Gyp		156		159		12. Pumping level below land surfaces: <u>160</u> ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>50+</u> g.p.m.
Medium sand		159		214		13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____
Yellow clay		214		216		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade
						15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From <u>5</u> ft. to <u>15</u> ft.
						16. Nearest source of possible contamination: <u>sanitary</u> ft. <u>60</u> Direction <u>N</u> Type <u>sewer line</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____
						17. Pump: _____ Not installed Manufacturer's name <u>Aermotor</u> Model number <u>SD12-100HP</u> <u>1</u> Volts <u>230</u> Length of drop pipe <u>180</u> ft. capacity <u>12</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>ABC Drilling, Inc 246</u> Business name License No. _____ Address <u>Scott City, KS 67871</u> Signed <u>Sylvan Ross</u> Date <u>7/2/77</u> Authorized representative
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 16 S R 38 E/W Sec 24 NW 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5