

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Groesbeck	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 14	Township number T 16	Range number S R 39	1/W																					
2. Distance and direction from nearest town or city: TRIBUNE Street address of well location if in city: 13 N 8 1/2 E 1/2 N				3. Owner of well: Guy Bohlen R.R. or street: City, state, zip code: Wallace, Kansas 67761																								
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. 2 1/2 in. Completion date _____ Well depth 183 ft. 11-10-76																								
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary																								
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																								
5. Type and color of material				9. Casing: Material Steel Height: Above ground _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 2 1/2 in. RMP _____ PVC _____ Weight 36 lbs./ft. Dia. 1 1/2 in. to 133 ft. depth <input checked="" type="checkbox"/> Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 2219																								
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:50%;">Type and color of material</th> <th style="width:10%;">From</th> <th style="width:10%;">To</th> </tr> </thead> <tbody> <tr> <td>Fine Sand, Sandy Clay</td> <td>100</td> <td>130</td> </tr> <tr> <td>M GRAVEL</td> <td>130</td> <td>151</td> </tr> <tr> <td>Sandy Clay</td> <td>151</td> <td>158</td> </tr> <tr> <td>Fine Sand, M Gravel</td> <td>158</td> <td>172</td> </tr> <tr> <td>M GRAVEL</td> <td>172</td> <td>177</td> </tr> <tr> <td>Chalc</td> <td>177</td> <td>183</td> </tr> </tbody> </table>				Type and color of material	From	To	Fine Sand, Sandy Clay	100	130	M GRAVEL	130	151	Sandy Clay	151	158	Fine Sand, M Gravel	158	172	M GRAVEL	172	177	Chalc	177	183	10. Screen: Manufacturer's name W.A. Brown Type Lower Dia. 1 1/2 Slot/gauze 1/8 x 7/8 Length 50 Set between 133 ft. and 183 ft. ft. and _____ ft. Gravel pack? Yes Size range of material 1/4 to 3/8			
				Type and color of material	From	To																						
Fine Sand, Sandy Clay	100	130																										
M GRAVEL	130	151																										
Sandy Clay	151	158																										
Fine Sand, M Gravel	158	172																										
M GRAVEL	172	177																										
Chalc	177	183																										
				11. Static water level: _____ mo./day/yr. 115 ft. below land surface Date 10-13-76																								
				12. Pumping level below land surfaces: 171 ft. after 5 hrs. pumping 800 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 800 g.p.m.																								
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____																								
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade																								
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.																								
				16. Nearest source of possible contamination: ft. _____ Direction _____ Type None Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																								
				17. Pump: Not installed Manufacturer's name Western Land Rotten Model number 8M HP 100 Volts 480 Length of drop pipe 170 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																								
(Use a second sheet if needed)																												
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. StH Drilling Co Inc 1166 Business name _____ License No. _____ Address Woodland Kansas Signed Bill Cufford Date _____ Authorized representative 11-12-76																								
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley																												

T 16
 R 39
 W 1
 Sec 14
 NE 1/4
 NW 1/4
 SE 1/4
 SW 1/4