

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Greeley	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 18	Township number T 16 S R 39 E/W	Range number 39
2. Distance and direction from nearest town or city: 13 mi. N. 2 mi. East, & 1/4 mi. South of Tribune, Kansas.			3. Owner of well: L. A. Peters			
Street address of well location if in city:			R.R. or street:			
			City, state, zip code: Tribune, Kans. 67879			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date _____ Well depth 188 ft. 8-21-77		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material Steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight 40 lbs./ft. Dia. 16 in. to 178 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .219		
Overburden		0	75	10. Screen: Manufacturer's name _____ W. A. Brown Type Free-flo Dia. 16 Slot size _____ Length 10 ft. Set between 178 ft. and 188 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/4 - 5/8		
Sand & clay		75	190	11. Static water level: _____ mo./day/yr. 150 ft. below land surface Date 8-1-77		
Clay & sand & little hard lime		90	102	12. Pumping level below land surfaces: 186 ft. after 3 hrs. pumping 450 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 450 g.p.m.		
Clay & little lime (pink)		102	120	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Clay (white gum)		120	135	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
Clay, little fine sand & cemented sand		135	145	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Sand, cemented sand(hard) & 2' clay		145	158	16. Nearest source of possible contamination: ft. _____ Direction _____ Type None Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Clay		158	163	17. Pump: _____ Not installed Manufacturer's name Layne & Bowler Model number 81524K HP 25 Volts 230 Length of drop pipe 180 ft. capacity 230 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sand		163	169	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ark Valley Pump & supply 123 Business name _____ License No. _____ Address Box 235 Holly, Colo. Signed <i>[Signature]</i> Date _____ Authorized representative		
Clay, 1' sand & little cemented sand		169	178			
Sand		178	182			
Clay & lime		182	185			
Shale		185	188			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T
R
Sec
1/4
1/4
1/4
1/4
 18
39
16
188