

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Greeley	Fraction NE 1/4 SE 1/4 NE 1/4	Section number 24	Township number T 16 S R 39 E	Range number 39 E
2. Distance and direction from nearest town or city: 12N, 2W, 1/4 S of Selkirk, Kansas				3. Owner of well: Wendale McAllaster R.R. or street: 3717 - 21st Street City, state, zip code: Great Bend, KS 67530		
4. Locate with "X" in section below: Sketch map: X well 1/2 mi. Septic				6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>172</u> ft. <u>10-14-76</u>		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>31.62</u> lbs./ft. Dia. <u>16</u> in. to <u>172</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>188</u>		
				10. Screen: Manufacturer's name _____ <u>Free Flow</u> Type <u>Prime Steel</u> Dia. <u>16 in.</u> Gauge <u>125</u> Length <u>40 ft.</u> Set between <u>132</u> ft. and <u>172</u> ft. Gravel pack? <input checked="" type="checkbox"/> YES Size range of material <u>3/4-1/4</u>		
				11. Static water level: _____ mo./day/yr. <u>85</u> ft. below land surface Date <u>8-25-76</u>		
				12. Pumping level below land surfaces: <u>145</u> ft. after <u>8</u> hrs. pumping <u>500</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>500</u> g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
				15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: ft. <u>2640</u> Direction <u>SW</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name <u>Western Land Roller</u> Model number <u>GE</u> HP <u>40</u> Volts <u>440</u> Length of drop pipe <u>165</u> ft. capacity <u>500</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Weishaar Drilling</u> <u>232</u> Business name License No. Address <u>Scott City, KS 67871</u> Signed <u>[Signature]</u> Date _____ Authorized representative <u>11-3-76</u>		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

16 39 E
 R
 24
 Sec
 1/4 1/4 1/4
 NESENE