

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County: Greeley		Fraction: NE 1/4 NE 1/4 SW 1/4		Section number: 5	Township number: T 16 S	Range number: R 40 E/W
2. Distance and direction from nearest town or city: 15 north 1/2 west of Tribune, Kansas Street address of well location if in city:				3. Owner of well: Hayes McDonald R.R. or street: City, state, zip code: Tribune, Kansas 67879		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 9 in. Completion date: 5/21/79 Well depth: 197 ft.		
5. Type and color of material		From		To		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material: Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface: 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight: 1.8 lbs./ft. Dia. 5 in. to 177 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 250
						10. Screen: Manufacturer's name: Jess & Lowell Type: RMP Dia. 5" Slot/gauze: 1/16" Length: 20" Set between 177 ft. and 197 ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material: 1/4 x 1/8"
						11. Static water level: 119 ft. below land surface Date: 5/11/79 mo./day/yr.
						12. Pumping level below land surfaces: 120 ft. after 4 hrs. pumping 4 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 50 g.p.m.
						13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.
						16. Nearest source of possible contamination: ft. 2600' Direction East Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: Not installed Manufacturer's name: Aeromotor Model number: 144 HP: 1/4 Length of drop pipe: 144 ft. capacity: g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal Cylinder Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling & Supply 232 Business name: License No. _____ Address: Scott City, Kansas 67871 Signed: <i>[Signature]</i> Date: 5/21/79 Authorized Representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 16 R 40 E Sec 5 NENE SW 1/4 1/4 1/4 1/4