

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Greeley</b>	Fraction <b>SW 1/4 NE 1/4 NE 1/4</b>	Section number <b>8</b>	Township number <b>T 16 S</b>	Range number <b>R 40 E/W</b>
2. Distance and direction from nearest town or city: <b>1 1/4 mi. north &amp; 1/4 mi. west</b>			3. Owner of well: <b>Kim Voth</b>		
Street address of well location if in city:			R.R. or street:		
			City, state, zip code: <b>Tribune, Kans. 67879</b>		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. <b>26</b> in. Completion date _____ Well depth <b>178</b> ft. <b>10-2-75</b>		
			7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____		
5. Type and color of material			9. Casing: Material <b>steel</b> Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP _____ PVC _____ Weight <b>40</b> lbs./ft. Dia. <b>16</b> in. to <b>118</b> ft. depth Wall Thickness: inches or _____ Dip: _____ in. to _____ ft. depth gage No. <b>219</b>		
			10. Screen: Manufacturer's name _____ <b>W. A. Brown</b> Type <b>Free Flo</b> Dia. <b>16</b> Slot/gauze <b>slot</b> Length <b>60</b> ft. Set between <b>118</b> ft. and <b>178</b> ft. _____ ft. and _____ ft. Gravel pack? <b>yes</b> Size range of material <b>5/8</b>		
			11. Static water level: _____ mo./day/yr. <b>120</b> ft. below land surface Date <b>10-27-75</b>		
			12. Pumping level below land surfaces: <b>160</b> ft. after <b>3</b> hrs. pumping <b>900</b> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <b>1000</b> g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____		
			14. Well head completion: _____ Pitless adapter _____ <b>18</b> inches above grade		
			15. Well grouted? <b>yes</b> With: _____ Neat cement <input checked="" type="checkbox"/> Bentonite _____ Concrete _____ Depth: From <b>0</b> ft. to <b>10</b> ft.		
			16. Nearest source of possible contamination: ft. _____ Direction _____ Type <b>None</b> Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No _____		
			17. Pump: _____ Not installed Manufacturer's name <b>Layne</b> Model number <b>79279K</b> HP <b>100</b> Volts <b>440</b> Length of drop pipe <b>175</b> ft. capacity <b>900</b> g.p.m. Type: _____ Submersible <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____		
			18. Elevation:		
			19. Remarks:		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>ARK VALLEY PUMP &amp; SUPPLY 123</b> Business name _____ License No. _____ Address <b>Box 235 Holly, Colo.</b> Signed <b>W. A. Brown</b> Date <b>1/16/76</b> Authorized representative		

T 16  
 R 40 E  
 S 8  
 Sec 8  
 1/4 1/4 1/4  
 SUNNENE