


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Greeley	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 13	Township number T 16 S	Range number R 40 W
2. Distance and direction from nearest town or city: 13 Mi. N. & 3 E. Of Tribune, Kans.		3. Owner of well: Daniel Peters				
Street address of well location if in city:		R.R. or street:				
		City, state, zip code: Tribune, Kans. 67879				
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map:		6. Bore hole dia. 6 1/2 in. Completion date 12-15-79 Well depth 175 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 188 lbs./ft. Dia. 5 in. to 155 ft. depth Wall Thickness: inches or Dia. 1 in. to 175 ft. depth gage No. 188		
Top soil		0	15	10. Screen: Manufacturer's name Torch cut Type Steel Dia. 5 in. Slot/gauze 155 Length 20 ft. Set between 155 ft. and 175 ft. Gravel pack? No Size range of material		
Lime, Clay, & Little sand		15	60	11. Static water level: 135 ft. below land surface Date 12-15-79 mo./day/yr.		
Sand		60	65	12. Pumping level below land surfaces: 155 ft. after 12 hrs. pumping 15 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 25 g.p.m.		
Clay & little Lime		65	120	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
Clay, Lime, & 4' Cemented Sand		120	150	14. Well head completion: Pitless adapter 12 Inches above grade		
Cemented Sand		150	152	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Clay		152	157	16. Nearest source of possible contamination: ft. 150 Direction east Type sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sand & Clay, Clay & Lime, & Cemented sand		157	162	17. Pump: Not installed Manufacturer's name Reta Model number 17D HP 1 Volts 230 Length of drop pipe 165 ft. capacity 15 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Cemented Sand (very hard)		162	163			
Clay (yellow)		163	169			
Shale		169	175			
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ark Valley Pump & Supply 123 Business name Box 235 Holly, Co. 81047 license No. Address Wes Smith 2-29-80 Signed Wes Smith Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						