## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction SE 1/4 SE 1/4 SE 1/4		Section number		Township number Range number	
1. Location of well:	Greeley					T 16 S R 42 E/W	
N. Distance and direction from nearest town or city:    Note				ner of well: Eddie Floyd r street:			
				ite, zip	code:	Tribune, Kans. 67879	┨ .
4. Locate with "X" in section below: Sketch map:				and the second		6. Bore hole dia, 28 in. Completion date Well depth 236 ft. 9-29-75	
NW NE E 507						7 Cable tool Rotary Driven Dug Hollow rod Jetted Bored X Reverse rotary	
						8. Use: Domestic Public supply Industry X Irrigation Air conditioning Stock	
sw	SE	A Commence of the second				9. Casing: Material Steel Height: Above or KANX	1
<u> </u>		eria. Herrita de la proposición de la composición del composición de la composición	or and a superposition		*.	Threaded Welded is uniface in.  RMP PVC Weight lbs./ft.  Dia. 16 in. to 196 ft. depth   Wall Thickness: inches or	
5. Type and color of				From	To	Diain. toft. depth yall inickness; inches orft. depth gage No219	
						Screen: Manufacturer's name W. A. Brown	.]
Overburden				0	146	Type Free Flo Slot/gauze Slot Length X X 40 ft	
Clay & cemented sand streaked				146	175	Set between $\times 196$ ft. and $\times 236$ ft.	.]
Sandy clay			175	178	ft. andft.  Gravel pack? <u>Yes</u> Size range of material5/8	<u>'</u>	
Sand			178	230	11. Static water level: mo./day/yr. 170_ft. below land surface Date 10-1-75_		
Cemented sand & broken Line				230	234	12. Pumping level below land surfaces: 225 ft. after 4 hrs. pumping 900 g.p.m.	]
Shale				234	236	ft. after hrs. pumping g.p.m. Estimated maximum yield 900 g.p.m.	
						13. Water sample submitted: mo./day/yr.  Yes X No Date	┪
						14. Well head completion:	1
						Pitless adapter	d
						With: Neat cement X Bentonite Concrete Depth: From 6 ft. to 10 ft.	-
						16. Nearest source of possible contamination: ft Direction Type None	1
	, , , , , , , , , , , , , , , , , , ,					Well disinfected upon completion? X Yes X No	<u>.</u>
						17. Pump: Layne Not installed  Manufacturer's name Layne  Model number 79473K up 75 Valu 440	70
						Length of drop pipe 220 ft. capacity 800 g.p.m.	
						Type: Submersible X Turbine	
	(Use a second	sheet if needed)				Jet Reciprocating Centrifugal Other	ک <b>ۇ</b> د
18. Elevation: 19. Remtiks:					Water well contractor's certification: This well was drilled under my jurisdiction and this report	1	
Topography:						is true to the best of my knowledge and belief.  ARK VALLEY PUMP & SUPPLY 123  Business name License No.	\$
Slope X Upland		,				Business name  Address  Box 235 Holly, Colo.  Signed  Date  Date	7
Valley	us and nink copies to the Department					Authorized representative	] ≥