


USE TYPEWRITER OR BALL  
POINT PEN—PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Greeley</b>	Fraction <b>SE 1/4 SE 1/4 NW 1/4</b>	Section number <b>22</b>	Township number <b>T 16 S</b>	Range number <b>R 42 E</b>
2. Distance and direction from nearest town or city: <b>13 N., 10 1/2 W., of Tribune.</b>			3. Owner of well: <b>V.M. Young</b> R.R. or street: <b>Tribune, Ks. 67879</b> City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>26</b> in. Completion date <b>7-8-77</b> Well depth <b>240</b> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <b>steel</b> Height: Above <del>ground</del> <b>12</b> in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>24 1/2</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>250</b>		
				10. Screen: Manufacturer's name <b>Johnson</b> Type <b>galv.</b> Dia. <b>16"</b> Slot/gauge <input type="checkbox"/> Length <b>20</b> ft. Set between <b>210</b> ft. and <b>230</b> ft. Perf: <b>200-210</b> ft. and <b>230-240</b> ft. Gravel pack? <b>yes</b> Size range of material <b>3" down</b>		
5. Type and color of material		From	To	11. Static water level: <input type="checkbox"/> mo./day/yr. <b>197</b> ft. below land surface Date <b>6-2-77</b>		
				12. Pumping level below land surfaces: <b>214</b> ft. after <b>4</b> hrs. pumping <b>425</b> g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield <b>425</b> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: Pitless adapter <b>12</b> inches above grade		
				15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
				16. Nearest source of possible contamination: <b>N/A</b> ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: Not installed Manufacturer's name <b>Goulds-US Pump</b> Model number <b>10 JMC</b> HP <b>60</b> Volts Length of drop pipe <b>220</b> ft. capacity <b>400</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drilling Co. 208</b> Business name License No. Address <b>Box A Garden City, Ks.</b> Signed <b>Steve DeFoy</b> Date <b>7-30-77</b> Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

16 42 E  
R  
22 SE  
1/4 1/4 1/4

*The*  
*Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8069 • P.O. Box A • GARDEN CITY, KANSAS 67846

V. M. YOUNG  
GREELEY COUNTY  
5-5-77

Location: NW 22-16-42 NW corner 1000 Ft.  
Static Water Level- 190'

## Test #5

0	1	Top soil
1	7	Brown clay
7	18	Brown sandy clay
18	37	Brown sandy clay mixed with rock
37	48	Med. sand to med. coarse gravel
48	86	Brown sandy clay
86	91	Fine to med. sand and gravel
91	95	Med. sand to med. coarse gravel mixed with rock
		Hard
95	114	Brown sandy clay hard pull down
114	124	Brown sandy clay sand traces hard
124	131	Fine sand 10% clay
131	136	Brown sandy clay
136	144	Fine to med. sand
144	163	Light brown sandy clay Hard
163	167	Fine to med. sand and gravel
167	189	Brown sandy clay
189	201	Fine to med. sand and gravel tight
201	208	Fine to med. sand and gravel
208	226	Fine to med. sand and gravel Tight
226	229	Fine to med. sand and gravel Hard
229	234	Brown sandy clay
234	237	Yellow clay
237	240	Shale