


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

|   |                         |   |  |   |                                 |
|---|-------------------------|---|--|---|---------------------------------|
| 1. Location of well:  | County<br><b>GREELY</b> | Section<br><b>NW 1/4 SE 1/4</b>   | Section number<br><b>24</b>  | Township number<br><b>T 16 S</b>  | Range number<br><b>R 43 E/W</b> |
| 2. Distance and direction from nearest town or city<br><b>13 North, 8 West of Tribune, 4/10 South of West Side of road 350'</b>                                 |                         | 3. Owner of well: <b>V.M. Young</b><br>R.R. or street: <b>Tribune, Ks 67879</b><br>City, state, zip code: |  |   |                                 |
| X Locate with "X" in section below:<br>N<br><br>W<br>E<br>S<br>1 Mile           |                         | Sketch map:   |  | 6. Bore hole dia. <b>26</b> in. Completion date <b>2-29-76</b><br>Well depth <b>272</b> ft.   |                                 |
| 5. Type and color of material   |                         | From  | To   | 7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug<br><input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary   |                                 |
|   |                         |   |  | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry<br><input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock<br><input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other  |                                 |
|   |                         |   |  | X Casing: Material <b>Steel</b> Height: Above or below<br>Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in.<br>RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>86.87</b> lbs./ft.<br>Dia. <b>16</b> in. to <b>273</b> ft. depth <input checked="" type="checkbox"/> All Thickness: inches or<br>Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth page No. <b>219</b>                      |                                 |
|   |                         |   |  | 10. <b>Johnson Division</b><br><b>Galv.</b> <b>16"</b><br>Type <input type="checkbox"/> Dia. <input type="checkbox"/><br>Slot/gauze <b>100</b> Length <b>20'</b><br>Set between <b>242</b> ft. and <b>262</b> ft.<br>Perf. <b>190-242</b> ft. and <b>262-272</b> ft.<br>Gravel pack? <b>yes</b> Size range of material <b>1/2" Down</b>   |                                 |
|   |                         |   |  | 11. Static water level: <input type="checkbox"/> mo./day/yr.<br><b>169</b> ft. below land surface Date <b>1-19-76</b>   |                                 |
|   |                         |   |  | 12. Pumping level below land surfaces:<br><b>230</b> ft. after <b>3</b> hrs. pumping <b>1300</b> g.p.m.<br>ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.<br>Estimated maximum yield <b>1300</b> g.p.m.  |                                 |
|   |                         |   |  | 13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>   |                                 |
|   |                         |   |  | 14. Well head completion: <b>12</b><br><input type="checkbox"/> Pitless adapter <input type="checkbox"/> inches above grade   |                                 |
|   |                         |   |  | 15. Well grouted? <b>yes</b><br>With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete<br>Depth: From <b>0</b> ft. to <b>10</b> ft.   |                                 |
|   |                         |   |  | 16. Nearest source of possible contamination: <b>N/A</b><br>ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/><br>Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No  |                                 |
|   |                         |   |  | 17. Pump: <input type="checkbox"/> Not installed<br>Manufacturer's name <b>Goulds US Pumps</b><br>Model number <b>12JHC</b> HP <b>125</b> Volts <input type="checkbox"/><br>Length of drop pipe <b>260</b> ft. capacity <b>1300</b> g.p.m.<br>Type:<br><input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine<br><input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating<br><input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |                                 |
|   |                         |   |  | (Use a second sheet if needed)  |                                 |
| 18. Elevation:  | 19. Remarks:            |   | 20. Water well contractor's certification:<br>This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.<br><b>Minter Wilson Drilling 208</b><br>Business name <b>P.O. Box A Garden City, Mo</b><br>Address <b>1000 S. 1st St.</b><br>Signed <b>[Signature]</b> Date <b>3-2-76</b><br>Authorized representative |   |                                 |
| Topography:<br><input type="checkbox"/> Hill<br><input checked="" type="checkbox"/> Slope<br><input type="checkbox"/> Upland<br><input type="checkbox"/> Valley |                         |   |  |   |                                 |

16-430-24 NUSESE  
1/4 1/4 1/4

Professionals

# MINTER-WILSON DRILLING CO.

INCORPORATED

Phone 276-8269

P.O. Box 493

GARDEN CITY, KANSAS 67846

V. M. YOUNG  
Greeley County  
12-29-75

Location: NE NE SE 24-16-43  
13 miles North, 8 miles West of Tribune, 1/10  
of a mile South of West side of road, 350 feet  
North of the corner

Static Water Level - 170'

## Test # 1

|     |     |   |
|-----|-----|---|
| 0   | 3   | Top Soil                                      |
| 3   | 63  | Brown Clay & White Rock                       |
| 63  | 77  | Fine to Med. Sand & Gravel                    |
| 77  | 113 | Brown Sandy Clay                              |
| 113 | 119 | Fine to Med. Sand & Gravel                    |
| 119 | 138 | Brown Sandy Clay                              |
| 138 | 176 | Fine to Med. Sand & Gravel (Tight) (15% Clay) |
| 176 | 183 | Brown Sandy Clay (Hard)                       |
| 183 | 210 | Fine to Med. Sand & Gravel, 10% Clay (Tight)  |
| 210 | 262 | Fine to Med. Sand & Gravel                    |
| 262 | 267 | Yellow Clay & Shale                           |

T.D. 272'