


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Location of well:	County Ellsworth	Fraction SW 1/4 SE 1/4 SE 1/4	Section number 21	Township number T 16 S R	Range number 6 W
Distance and direction from nearest town or city: 6 mi NORTH AND 1 mi WEST OF Langley, KS			3. Owner of well: HERBERT ANDROS		
Street address of well location if in city:			R.R. or street: 207 S. MAIN		
City, state, zip code: SOUTH HUTCHINSON KS 67501					
Locate with "X" in section below: N W E S 1 Mile Sketch map: 			6. Bore hole dia. 8 in. Completion date 12-1-77 Well depth 45 ft.		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			Casing: Material <input type="checkbox"/> Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 1 1/2 lbs./ft. Dia. 4 in. to 36 ft. depth Wall Thickness: inches or Dia. 4 in. to 45 ft. depth gage No. 1/4		
5. Type and color of material			10. Screen: Manufacturer's name Peerless Plastics		
			Type PVC Dia. 4"		
			Slot/gauze 1/32" Length 10'		
			Set between 25 ft. and 35 ft. ft. and ft.		
			Gravel pack? Yes Size range of material 1/4"		
Top soil			From 0 To 2		
Fine sand			From 2 To 28		
Sandstone			From 28 To 32		
Blue shale			From 32 To 45		
			11. Static water level: mo./day/yr. 24 ft. below land surface Date 12/2/77		
			12. Pumping level below land surfaces: 30 ft. after 1 1/2 hrs. pumping 10 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 25 g.p.m.		
			13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. 300 Direction NORTH Type Septic Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Peterson Irrigation 138A Business name License No. Address Box 150 Lindsborg KS Signed Mike Chambers Date 12-2 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T
R
W
E
S
E
1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5