

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ellsworth	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 11	Township number T 16 S R 8 E/W	Range number
X Distance and direction from nearest town or city: 3 mi. So. 1 1/8 mi. E. of Ellsworth, Ks. Street address of well location if in city:			3. Owner of well: David Snyder Rt. #2 R.R. or street: City, state, zip code: Ellsworth, Kansas 67439			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 11 in. Completion date _____ Well depth 101 ft. 4-14-78	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil		0	4	9. Casing: Material pvc Height: Above or below Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 4 1/2 in. to 101 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. .237		
Sand & Gravel		4	25	10. Screen: Manufacturer's name CertainFeed Type pvc Dia. <input checked="" type="checkbox"/> 4 1/2 Slot/g <input checked="" type="checkbox"/> 1/16 Length 41 Set between 60 ft. and 101 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8		
Shale		25	66	11. Static water level: _____ mo./day/yr. 18 ft. below land surface Date 4-14-78		
Sand rock		66	68	12. Pumping level below land surfaces: 99 ft. after 1 hrs. pumping 3 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 3 g.p.m.		
Iron Pyrite		68	71	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 4-14-78		
Little sand rock and shale		71	100	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Shale		100	114	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0-18 ft. to 38-42 ft.		
Red bed		114	120	16. Nearest source of possible contamination: ft. 200 Direction So. Type septic Well disinfected upon completion? HTH Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Kansas 67530 Signed Sandy K. Moore Date 4-18-78 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

16 8 14
K
Sec
1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5