


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

17 11 W 6 S W SW
T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Barton	Township name Independent SW 1/4 SWSW	Fraction	Section number 6	Town number 17	Range number 11
Distance and direction from nearest town or city: 5N 3W of Claflin			3 Owner of well: Mr. Steve Demel			
Street address of well location if in city:			Address: Route Claflin Kansas 67525			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: 172 ft. Date of completion: 11-28-75 Well diameter 9 in.
2 Type and color of material			From	To	5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Surface			0	3	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
Clay Brown			3	12	7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 4 Dia. 2.277 lbs./ft. 2.277 Weight 2.277 lbs./ft. 2.277 5 in. to 172 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Clay light brown			12	40	8 Screen: Manufacturer _____ Type _____ Dia. _____ Slot/gauze drilled Length 20 ft Set between 152 ft. and 172 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4	
clay light brown (sandy) 1 gal. P.M			40	43	9 Static water level: 152 ft. below land surface Date 11-28-75	
clay brown			43	46	10 Pumping level below land surfaces: 152 ft. after 1 hrs. pumping 12 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.	
Shale blue			46	87	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
shale blue hard & sandy			87	92	12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
sand rock water 3 gal PM			92	107	13 Well grouted? <input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 60 ft.	
shale gray			107	123	14 Nearest source of possible contamination: none ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
shale brown			123	135	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Jacuzzi Model number 1s4b HP 1 Volts 230 Length of drop pipe 150 ft. capacity 12 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
shale brown light			135	140	16 Remarks: elevation	
shale brown			140	145	Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	
shale light brown & sandy			145	150	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Jezeq Water Well Drig 191 Business name Holyrood, Kansas 67450 Address _____ Signed Joe Jezeq Date 12-12-75 Authorized representative	
sand rock (water)			150	172		
(use a second sheet if needed)						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

17 11 W 6 S W SW
MS SW