

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Barton	Fraction sw 1/4 sw 1/4 se 1/4	Section number 2	Township number T 17 S R 12 E	Range number 12																											
2. Distance and direction from nearest town or city: 2 north - 1/2 west of Odin, Ks.			3. Owner of well: Lawrence Rief																													
Street address of well location if in city:			R.R. or street: Rt. 1																													
4. Locate with "X" in section below:			City, state, zip code: Claflin, Ks. 67525																													
Sketch map: 			6. Bore hole dia. 10 in. Completion date 2-14-77 Well depth 120																													
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary																													
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:80%;"></th> <th style="width:10%;">From</th> <th style="width:10%;">To</th> </tr> </thead> <tbody> <tr> <td>Top soil</td> <td>0</td> <td>3</td> </tr> <tr> <td>Hard clay</td> <td>3</td> <td>16</td> </tr> <tr> <td>Soft brown clay</td> <td>16</td> <td>30</td> </tr> <tr> <td>Shale</td> <td>30</td> <td>70</td> </tr> <tr> <td>Good sand rock</td> <td>70</td> <td>83</td> </tr> <tr> <td>White clay</td> <td>83</td> <td>95</td> </tr> <tr> <td>Sand rock good</td> <td>95</td> <td>115</td> </tr> <tr> <td>Shale</td> <td>115</td> <td>120</td> </tr> </tbody> </table>				From	To	Top soil	0	3	Hard clay	3	16	Soft brown clay	16	30	Shale	30	70	Good sand rock	70	83	White clay	83	95	Sand rock good	95	115	Shale	115	120	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
	From	To																														
Top soil	0	3																														
Hard clay	3	16																														
Soft brown clay	16	30																														
Shale	30	70																														
Good sand rock	70	83																														
White clay	83	95																														
Sand rock good	95	115																														
Shale	115	120																														
			9. Casing: Material pvc Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 160 lbs./ft. Dia. 5 1/2 in. to 120 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 214																													
			10. Screen: Manufacturer's name Rief Perless Type pvc Dia. 5 1/2 Slot/gauze 1/16 Length 40 Set between 80 ft. and 120 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 - 3/8																													
			11. Static water level: <input type="checkbox"/> mo./day/yr. 60 ft. below land surface Date 2-14-77																													
			12. Pumping level below land surfaces: 80 ft. after 1 hrs. pumping 20 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 60 g.p.m.																													
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 2-14-77																													
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade																													
			15. Well grouted? <input checked="" type="checkbox"/> yes MNS With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.																													
			16. Nearest source of possible contamination: ft. 200 Direction SE Type septic tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																													
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																													
(Use a second sheet if needed)																																
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. Signed Freddie Nordson Date 2/2 Authorized representative																												
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley																																

T 17 S R 12 E
 Sec 2
 SW 1/4 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5