

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Rush	Fraction SW 1/4 SW 1/4 NE 1/4	Section number 24	Township number T 17 S	Range number R 20 E
2. Distance and direction from nearest town or city 2 1/2 west Hargrave, ks.			Owner of well: Jay Pfeifer R.R. or street: RR. McCracken, Ks. City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile			6. Bore hole dia. 9 in. Completion date: 4-27-79 Well depth: 45 ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			9. Casing: Material PVC Height: Above or below Threading: <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP: 5 PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: inches or Dia. 5 in. to 45 ft. depth gage No. .26		
10. Screen: Manufacturer's name Jet stream Type pvc Dia. 5 Slot .031 Length 10 Set between 35 ft. and 45 ft. ft. and 45 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1-2			11. Static water level: 35 ft. below land surface Date 4-27-79 mo./day/yr.		
12. Pumping level below land surfaces: 40 ft. after 1 hrs. pumping 5 g.p.m. ft. after 1 hrs. pumping 5 g.p.m. Estimated maximum yield 5 g.p.m.			13. Water sample submitted: 17 mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
14. Well head completion: 16 Pitless adapter 16 inches above grade			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
16. Nearest source of possible contamination: none ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Karst Water Well 199 Business name E. Hiway 40 Hays, ks. License No. Address Thel Karst Date 4-27-79 Signed Thel Karst Authorized representative		
19. Remarks: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5