

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Lane	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 25	Township number T 17 S R 28 E	Range number 28 E
2. Distance and direction from nearest town or city: 5E, 4 1/2 N, 3/4 E,			3. Owner of well: Ron Taylor		Street address of well location if in city: 1/4 S of Dighton, KS	
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 143 ft. 5-12-76	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material			From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay			0	22	9. Casing: Material Steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 10 in. RMP _____ PVC _____ Weight 31.67 lbs./ft. Dia. 16 in. to 143 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 188	
Gyp			22	40	10. Screen: Manufacturer's name Free Flow Type Prime Steel Dia. 16 in. <input checked="" type="checkbox"/> Gauze .125 Length 30 ft. Set between 113 ft. and 143 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 3/4-1/2	
Fine sd clay			40	50	11. Static water level: _____ mo./day/yr. 95 ft. below land surface Date 4-5-76	
Sd coarse			50	65	12. Pumping level below land surfaces: 114 ft. after 4 hrs. pumping 350 g.p.m. 116 ft. after 4 hrs. pumping 390 g.p.m. Estimated maximum yield 390 g.p.m.	
Fine sd clay			65	76	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
Sd rock			76	80	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade <input checked="" type="checkbox"/> Well grouted? _____ With: <input checked="" type="checkbox"/> Cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.	
Fine sd clay T			80	87	16. Nearest source of possible contamination: ft. 1980 Direction W Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Clay			87	93	17. Pump: _____ Not installed Manufacturer's name Western Land Roller Model number GE HP 25 Volts 460 Length of drop pipe 130 ft. capacity 390 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Fine sd clay			93	109	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ License No. _____ Address: Scott City, KS, 67871 Signed: [Signature] Date 7-21-76 Authorized representative	
Sd coarse			109	136		
Clay yellow			136	145		
Shale			145			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 17 S R 28 E
 Sec 25
 1/4 1/4 1/4