

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Lane	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 6	Township number T 17 S R 29 E	Range number 29 E
2. Distance and direction from nearest town or city: 2E of Healy, KS			3. Owner of well: Elginore Shay			
Street address of well location if in city: Healy, KS			City, state, zip code: Healy, KS 67850			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>26</u> in. Completion date <u>6-26-76</u> Well depth <u>175</u> ft.	
		<p style="text-align: center;"><i>X well</i> <i>↓ 1/2 mi.</i> Septic</p>			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay			36	9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP <u>16</u> PVC <input type="checkbox"/> Weight <u>31.67</u> lbs./ft. Dia. <u>16</u> in. to <u>175</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>188</u>		
Gyp			36	10. Screen: Manufacturer's name <u>Free Flow</u> Type <u>Prime Steel</u> Dia. <u>16 in.</u> <input checked="" type="checkbox"/> gauze <u>125</u> Length <u>40 ft.</u> Set between <u>135</u> ft. and <u>175</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>yes</u> Size range of material <u>3/4-1</u>		
Clay			40	11. Static water level: <u>112</u> ft. below land surface Date <u>6-1-76</u> mo./day/yr.		
Fine sd clay			55	12. Pumping level below land surfaces: <u>142</u> ft. after <u>4</u> hrs. pumping <u>520</u> g.p.m. <u>145</u> ft. after <u>4</u> hrs. pumping <u>530</u> g.p.m. Estimated maximum yield <u>530</u> g.p.m.		
Sd med			61	13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>		
Fine sd clay			70	14. Well head completion: <input type="checkbox"/> Pitless adapter <u> </u> inches above grade		
Sd rock			75	15. Well grouted? <input checked="" type="checkbox"/> With: <u> </u> cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.		
Sdy clay			82	16. Nearest source of possible contamination: ft. <u>2640</u> Direction <u>S</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Sd coarse			100	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Simmons</u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u>165</u> ft. capacity <u>530</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sd rock			107	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling <u>232</u> Business name License No. Address <u>Scott City, KS 67871</u> Signed <u> </u> Date <u>7-21-76</u> Authorized representative		
Clay			108	18. Elevation: <u>170</u> <u>172</u>		
Fine sd clay			110	19. Remarks: Clay yellow Shale		
Sd coarse			121	Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
Fine sd "loose"			140			
Fine sd clay			155			
Sd coarse (Use a second sheet if needed)			166			
Sd coarse			170			
Sd coarse			172			

T
R
Sec
1/4 1/4 1/4

17 29 E 29 S

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5