


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Lane	Fraction SW 1/4 SE 1/4 SW 1/4	Section number 35	Township number T 17 S	Range number R 29 E
2. Distance and direction from nearest town or city: 3N, 2W of			3. Owner of well: Gerald Riley			
Street address of well location if in city: Dighton, KS			R.R. or street: City, state, zip code: Dighton, KS 67839			
4. Locate with "X" in section below: 			Sketch map: X well 1/2 mi. Septic			6. Bore hole dia. 24 in. Completion date 7-12-76 Well depth 118 ft.
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Clay			0	19	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Gyp			19	43	9. Casing: Material Steel Height: 10 ft. or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 17.5 lbs./ft. Dia. 12 in. to 118 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 134	
Fine sd			43	47	10. Screen: Manufacturer's name Goulds Johnson Type Prime Steel Dia. 12 in. <input checked="" type="checkbox"/> gauze .100 Length 20 ft. Set between 98 ft. and 118 ft. ft. and <input type="checkbox"/> ft.	
Sd rock			47	54	Gravel pack? yes Size range of material 1-5/8	
Fine sd clay			54	73	11. Static water level: <input type="checkbox"/> mo./day/yr. 68 ft. below land surface Date 6-22-76	
Sd rock H			73	76	12. Pumping level below land surfaces: 96 ft. after 8 hrs. pumping 350 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 350 g.p.m.	
Med sd			76	89	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
Fine sd clay			89	100	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> inches above grade	
Sd coarse			100	114	<input checked="" type="checkbox"/> Well grouted? <input type="checkbox"/> With: <input checked="" type="checkbox"/> cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.	
Clay yellow			114	121	16. Nearest source of possible contamination: ft. 2640 Direction SW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Shale			121		17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number UH66ML HP 15 Volts 460 Length of drop pipe 105 ft. capacity 350 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name License No. Address Scott City, KS 67871 Signature [Signature] Date 7-22-76 Authorized representative	
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5