


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Lane</b>	Fraction <b>NW 1/4 SW 1/4 SE 1/4</b>	Section number <b>35</b>	Township number <b>T 17 S R 29 E</b>	Range number <b>29 E</b>
2. Distance and direction from nearest town or city: <b>3N, 1 1/2 W, 1/4 N of</b>		3. Owner of well: <b>Gerald Riley</b>			
Street address of well location if in city: <b>Dighton, KS</b>		City, state, zip code: <b>Dighton, KS 67839</b>			
4. Locate with "X" in section below: 		Sketch map: <b>X well 3 1/4 mi.</b> <b>Septic</b>		6. Bore hole dia. <b>24</b> in. Completion date <b>7-12-76</b> Well depth <b>116</b> ft.	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Clay		0	16	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Gyp		16	30	9. Casing: Material <b>Steel</b> Height: <b>10</b> ft. below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>10</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>17.5</b> lbs./ft. Dia. <b>12</b> in. to <b>116</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>134</b>	
Clay		30	39	10. Screen: Manufacturer's name <b>Johnson</b> Type <b>Galv. Steel</b> Dia. <b>12 in.</b> Gouge <b>.100</b> Length <b>20 ft.</b> Set between <b>96</b> ft. and <b>116</b> ft. ft. and <input type="checkbox"/> ft.	
Sd coarse		39	55	Gravel pack? <b>yes</b> Size range of material <b>1/4-5/8</b>	
Sd rock		55	59	11. Static water level: <b>68</b> ft. below land surface Date <b>6-19-76</b> mo./day/yr.	
Fine sd clay		59	89	12. Pumping level below land surfaces: <b>96</b> ft. after <b>8</b> hrs. pumping <b>350</b> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <b>350</b> g.p.m.	
Sd coarse		89	112	13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
Yellow		112	115	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade <input checked="" type="checkbox"/> Well grouted? <input type="checkbox"/> With: <input checked="" type="checkbox"/> cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>15</b> ft.	
(Use a second sheet if needed)				16. Nearest source of possible contamination: ft. <b>3960</b> Direction <b>SW</b> Type <b>Septic</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: Not installed Manufacturer's name <b>Goulds</b> Model number <b>UH66ML34</b> HP <b>15</b> Volts <b>460</b> Length of drop pipe <b>105</b> ft. capacity <b>350</b> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Weishaar Drilling</b> <b>232</b> Business name License No. Address <b>Scott City, KS 67871</b> Signed <b>[Signature]</b> Date <b>7-22-76</b> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5