WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Konsas 66620

	County	Fraction		Section number		Township number Range number			
1. Location of well:	Lane	NE 1/4 NE 1/4 NW	1/4	2		т 17 s	R 30	₽ ®	
2. Distance and direction from nearest town or city: 1N, ½E of				3. Owner of well:		Sharp Farms			
Street address of well location if in city: Healy, Kansas				R.R. or street: City, state, zip cade:		Healy, KS 67850			
4. Locate with "X" in section below: Sketch map:						6. Bore hole dio. <u>26</u> in. Completion date Well depth <u>178</u> ft. <u>3-4-77</u>			
Je Well — See						7 Cable tool Rotary Driven Dug Hollow rad Jetted Bored Reverse rotary			
Septe					7	8. Use: Domestic Public supply Industry X Irrigation Air conditioning Stock Lawn Oil field water Other			
sw se						9. Casing: Material Steel Height: Above r below Threaded Welded X Surface 10 in.			
S						RMPPVCWeight_31_67_lbs./ft. Dia.16_in. to 178rt. depth Woll Thickness: inches or			
5. Type and color of material					То	Dia in. to ft. depth gage No 188			
) .t.1	7 6	Ţ.,			10. Screen: Manufacturer's n			
Clay		y na magai ^{the} and make out of consideration		0	20	Galv. & Frime	Bio. 16	in.	
Gyp				20	25	Slot gauze 100 & 125 Length 30 ft. Set between 148 ft. and 178 ft.			
Clay				25	52	ft. andft. Gravel pack? YES Size range of material 3/4-1/4			
Sd coarse				52	60	11. Static water level: mo./day/yr.			
State 1 to 10 to 1					68	119 ft. below land surface Date 12-4-76			
Clay Fine ed clay				60	120	164 ft. after 4 hrs. pumping 340 g.p.m. 159 ft. ofter 4 hrs. pumping 350 g.p.m.			
Time Su Cital						Estimated maximum yield			
Sd coarse				120	150	13. Water sample submitted: mo./day/yr. Yes v No Date			
Fine sd clay				150	155	14. Well head completion:			
Fine sd good				155	167	Pitless adapter Inches above grade 15. Well grouted? Yes			
Sd coarse				167	177	With: X Neat cement Bentonite Concrete Pepth: From 0 ft. to ft.			
Clay yellow				177	180	16. Negrest source of possible contamination: ft. 2640 Direction East Type Septic			
Shale				180		Well disinfected upon completion? X YesNo			
						17. Pump: Manufocturer's name West	Not installed ern Land Ro	ller " (
						Madel number	HP Vol	ts	
						Length of drop pipe	tt. capacity	g.p.m.	
						Submersible	X Turbine	1 1	
	(Use a second s	heet if needed)				Jer Centrifugal	Recipro	Sound No.	
18. Elevation:	19. Remarks:					20. Water well contractor's of This well was drilled under m		report	
Topography:						is true to the best of my knowledge and belief.			
Hill						Business name	Lic	ense No	
						Address Cott Vit	6787		
Valley						Signer Authorized rep	resentative 3-29-		
Forward the white, blu	ue and pink copies to the Department	of Health and Environment					Form WW	c-5) E	