

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction NW 1/4 NE 1/4 NE 1/4	Section number 12	Township number T 17 S R 31 E	Range number 31
2. Distance and direction from nearest town or city: 8N, 11 3/4 E of			3. Owner of well: Terry Craner			
Street address of well location if in city: Scott City, KS			R.R. or street: City, state, zip code: Healy, KS 67850			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 175 ft. 2-25-76		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>		
				9. Casing: Material Steel Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.62 lbs./ft. Dia. 16 in. to 175 ft. depth Wall Thickness: inches 1.88 Dia. _____ in. to _____ ft. depth Gage No. _____		
5. Type and color of material		From	To	10. Screen: Manufacturer's name Free Flow Type Prime Steel Dia. 16 in. Slot/Gauze 125 Length 30 ft. Set between 145 ft. and 175 ft. ft. and _____ ft. Gravel pack? yes Size range of material 3/4 - 1/2		
Clay		0	32	11. Static water level: _____ no./day/yr. 103 ft. below land surface Date 1-2-76		
Gyp		32	41	12. Pumping level below land surfaces: 144 ft. after 4 hrs. pumping 490 g.p.m. 151 ft. after 4 hrs. pumping 535 g.p.m. Estimated maximum yield 535 g.p.m.		
Clay		41	49	13. Water sample submitted: _____ no./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
Sd rock		49	57	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade		
Clay		57	65	15. Well grouted? <input type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Rock H		65	83	16. Nearest source of possible contamination: ft. 660 Direction E Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Fine sd clay		83	98	17. Pump: _____ Not installed Manufacturer's name Western Land Roller Model number _____ HP _____ Volts _____ Length of drop pipe 160 ft. capacity 535 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Clay		98	105			
Fine sd clay		105	140			
Fine sd		140	152			
Sd coarse		152	161			
Clay		161	165			
Sd coarse		165	169			
Clay yellow		169	171			
Shale		171				
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ License No. _____ Address Scott City, KS 67871 Signature <i>[Signature]</i> Date 7-20-76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5